

Facility Summary in CASCADE County in the City of BELT

Location: BELT PUBLIC SCHOOLS DIST 29 UST
1 CHURCH ST
BELT, MT 59412 CASCADE

Sys Fac ID: 07-04613

Last Inspected On: 4/2/2014

Operating Permit Renewal Date: 8/4/2017

Contact: Kelvin Johnson, (406) 277-3351

Owners/Operators: School Dist 29 Belt, Owner

(406)-277-3351

PO BOX 197

BELT MT 59412-0197

Kathleen Prody, UST Class A Operator

April Wells, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	27	10/1/1988	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
422		6/6/2013	None	Double-Walled	Yes
Currently in Use			Not Required	U.S. Suction	Galvanic
Heating Oil		6/6/2013	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
10,000			EECO 1500 , EMCO Electronics		

Facility Summary in CASCADE County in the City of BELT

Location: MALMSTROM AFB A 2
US HIGHWAY 87/89
BELT, MT 59412 CASCADE

Sys Fac ID: 07-08976

Last Inspected On: 9/22/2014

Operating Permit Renewal Date: 10/7/2017

Contact: Jim Hodges,

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Leigland, UST Class A Operator
James Leigland, UST Class B Operator
Lana Hedlund, UST Class B Global Operator
Mark W Johnson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	23	6/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
109		9/4/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			ILS-350 , Veeder Root		

Facility Summary in CASCADE County in the City of BELT

Location: MALMSTROM AFB A 10
US HIGHWAY 87/89
BELT, MT 59412 CASCADE

Sys Fac ID: 07-08984

Last Inspected On: 9/22/2014

Operating Permit Renewal Date: 10/7/2017

Contact: Jim Hodges,

Owners/Operators: 341 CES CEANQ, Owner

(406)-731-6188

39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator

Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	23	5/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
115		9/4/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			ILS-350 , Veeder Root		

Facility Summary in CASCADE County in the City of BELT

Location: MALMSTROM AFB A 11
US HIGHWAY 87/89
BELT, MT 59412 CASCADE

Sys Fac ID: 07-08985

Last Inspected On: 9/22/2014

Operating Permit Renewal Date: 9/25/2017

Contact: Jim Hodges,

Owners/Operators: 341 CES CEANQ, Owner

(406)-731-6188

39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator

Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	23	5/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
116		9/4/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			ILS-350 , Veeder Root		

Facility Summary in CASCADE County in the City of BELT

Location: BELT VALLEY GROCERY

65 CASTNER STREET

BELT, MT 59412 CASCADE

Sys Fac ID: 07-13653

Last Inspected On: 8/9/2013

Operating Permit Renewal Date: 11/29/2016

Contact: Reed Throckmorton, (406) 277-3523

Owners/Operators: Harry L Throckmorton, Owner

(406)-277-3523

PO BOX 441

BELT MT 59412-0441

Reed Throckmorton, Owner/Operator

(406)-277-3523

PO BOX 441

BELT MT 59412

Reed Throckmorton, UST Class A Operator

Reed Throckmorton, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	20	10/1/1995	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4469		6/8/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
6,000					
2	20	10/1/1995	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4468		6/8/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
6,000					

Facility Summary in CASCADE County in the City of BLACK EAGLE

Location: MOUNTAIN VIEW COOP BLACK EAGLE
2200 OLD HAVRE HWY
BLACK EAGLE, MT 59414 CASCADE

Sys Fac ID: 07-04232

Last Inspected On: 4/23/2013

Operating Permit Renewal Date: 8/4/2016

Contact: Buck Pardis, (406) 453-2435

Owners/Operators: Mountain View Coop, Owner

(406)-453-2435

ATTN DAVE DOUGLAS
2200 OLD HAVRE HWY
BLACK EAGLE MT 59414-1043

Dan Morano, UST Class A Operator

Pat Trainor, UST Class A Operator

Pat Trainor, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
7	18	12/2/1997	Fiberglass Reinforced Plastic	No Piping	High Level Alarm
1015			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	Yes
12,000					
8	18	12/2/1997	Fiberglass Reinforced Plastic	No Piping	High Level Alarm
1016			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
12,000					
9	18	12/2/1997	Fiberglass Reinforced Plastic	No Piping	High Level Alarm
1017			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	Yes
4,000					
10	18	12/2/1997	Fiberglass Reinforced Plastic	No Piping	High Level Alarm
1018			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
4,000					

Facility Summary in CASCADE County in the City of BLACK EAGLE

Location: MOUNTAIN VIEW COOP BLACK EAGLE
2200 OLD HAVRE HWY
BLACK EAGLE, MT 59414 CASCADE

Sys Fac ID: 07-04232
Last Inspected On: 4/23/2013
Operating Permit Renewal Date: 8/4/2016

Contact: Buck Pardis, (406) 453-2435

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
11	18	12/2/1997	Fiberglass Reinforced Plastic	No Piping	High Level Alarm
1019			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
4,000					
12	18	12/2/1997	Fiberglass Reinforced Plastic	No Piping	High Level Alarm
1020			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
4,000					

Facility Summary in CASCADE County in the City of CASCADE

Location: TOMS IGA
130 1ST ST N
CASCADE, MT 59421 CASCADE

Sys Fac ID: 07-04148

Last Inspected On: 8/9/2013

Operating Permit Renewal Date: 9/20/2016

Contact: Dale Klock, (406) 468-2252

Owners/Operators: DTK Foods Inc, Owner (406)-468-2252 PO BOX 268
CASCADE MT 59421-0268
Irene Strandell, UST Class A Operator
Irene Strandell, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	18	5/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
1490		7/30/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000					
5	18	5/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
1491		7/30/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
6,000					
6	18	5/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
1492		7/30/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
5,000					
7	18	5/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
1493		7/30/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
6,000					

Facility Summary in CASCADE County in the City of CASCADE

Location: TOMS IGA
130 1ST ST N
CASCADE, MT 59421 CASCADE

Sys Fac ID: 07-04148

Last Inspected On: 8/9/2013

Operating Permit Renewal Date: 9/20/2016

Contact: Dale Klock, (406) 468-2252

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
8	18	5/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
1494		7/30/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
5,000					

Facility Summary in CASCADE County in the City of CASCADE

Location: OLSON FARM
430 KLOCK RD
CASCADE, MT 59421 CASCADE

Sys Fac ID: 07-04520

Last Inspected On: 9/9/2014

Operating Permit Renewal Date: 3/7/2018

Contact: Cory Olson, (406) 899-8525

Owners/Operators: Cory Olson, Owner/Operator

1040 10 MILE ROAD
CASCADE MT 59421

Cory Olson, UST Class A Operator

Cory Olson, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	16	4/1/1999	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4053			None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Gasoline		9/9/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		10/16/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in CASCADE County in the City of CASCADE

Location: MALMSTROM AFB G 3
INTERSTATE 15
CASCADE, MT 59421 CASCADE

Sys Fac ID: 07-09043

Last Inspected On: 9/17/2015

Operating Permit Renewal Date: 9/22/2018

Contact: Jim Hodges,

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator

James Hodges, UST Class A Operator

Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	26	6/21/1989	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
118		9/9/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in CASCADE County in the City of CASCADE

Location: MALMSTROM AFB G 4
INTERSTATE 15
CASCADE, MT 59421 CASCADE

Contact: Jim Hodges,

Sys Fac ID: 07-09044
Last Inspected On: 9/17/2015
Operating Permit Renewal Date: 9/22/2018

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	23	5/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
119		9/9/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in CASCADE County in the City of CASCADE

Location: MALMSTROM AFB G 5
INTERSTATE 15
CASCADE, MT 59421 CASCADE

Sys Fac ID: 07-09045

Last Inspected On: 9/17/2015

Operating Permit Renewal Date: 9/22/2018

Contact: Jim Hodges,

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator

James Hodges, UST Class A Operator

Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	23	5/1/1992	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
120		9/9/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in CASCADE County in the City of CASCADE

Location: MALMSTROM AFB I 1
HIGHWAY 330
CASCADE, MT 59421 CASCADE

Sys Fac ID: 07-09063

Last Inspected On: 9/8/2015

Operating Permit Renewal Date: 9/22/2018

Contact: Jim Hodges,

Owners/Operators: 341 CES CEANQ, Owner

(406)-731-6188

39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Ricardo Andrellon, UST Class B Operator
Glen Beck, UST Class B Operator
Allen Brooks, UST Class B Operator
Jonathan Buesch, UST Class B Operator
John Corbett, UST Class B Operator
David Cosner, UST Class B Operator
Ryan Cox, UST Class B Operator
Brian Day, UST Class B Operator
David Degolier, UST Class B Operator
Patrick Ellis, UST Class B Operator
Hudson English, UST Class B Operator
Paul Floyd, UST Class B Operator
Dustin Hemingway, UST Class B Operator
Aaron Hill, UST Class B Operator
Shane Hofstad, UST Class B Operator
Bethany Kent, UST Class B Operator
James Knudsen, UST Class B Operator
Ryan Kofoed, UST Class B Operator
Jeff Laird, UST Class B Operator
Damon McCarty, UST Class B Operator
Kieth McIlwain, UST Class B Operator
Brian McVay, UST Class B Operator
Ronald Miller, UST Class B Operator
Michael Murieen, UST Class B Operator
Jeff Nelson, UST Class B Operator
Patrick Noppenberg, UST Class B Operator
Shawn O'Grady, UST Class B Operator
Chris Ploof, UST Class B Operator
Issac Price, UST Class B Operator
Brian Rayner, UST Class B Operator

Facility Summary in CASCADE County in the City of CASCADE

Location: MALMSTROM AFB I 1
HIGHWAY 330
CASCADE, MT 59421 CASCADE

Sys Fac ID: 07-09063

Last Inspected On: 9/8/2015

Operating Permit Renewal Date: 9/22/2018

Contact: Jim Hodges,
Cameron Smith, UST Class B Operator
Jimmy Sonefelt, UST Class B Operator
Michael Stokes, UST Class B Operator
Jason Vike, UST Class B Operator
James Wooderchak, UST Class B Operator
Paul Ziemba, UST Class B Operator
Paul Floyd, UST Class B Global Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	53	6/2/1962	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
125		6/16/2014	Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Impressed Current
Diesel		9/28/2015	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Vapor Monitoring	

Facility Summary in CASCADE County in the City of CASCADE

Location: MALMSTROM AFB I 3
ROAD 330
CASCADE, MT 59421 CASCADE

Sys Fac ID: 07-09065

Last Inspected On: 9/8/2015

Operating Permit Renewal Date: 9/22/2018

Contact: Jim Hodges,

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536
Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	24	10/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
127		6/16/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in CASCADE County in the City of CASCADE

Location: MALMSTROM AFB I 4
ROAD 330
CASCADE, MT 59421 CASCADE

Sys Fac ID: 07-09066

Last Inspected On: 9/8/2015

Operating Permit Renewal Date: 9/22/2018

Contact: Jim Hodges,

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536
Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	24	10/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
128		6/16/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in CASCADE County in the City of CASCADE

Location: MALMSTROM AFB I 5
ROAD 330
CASCADE, MT 59421 CASCADE

Sys Fac ID: 07-09067

Last Inspected On: 9/8/2015

Operating Permit Renewal Date: 9/22/2018

Contact: Jim Hodges,

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536
Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	24	10/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
129		6/16/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in CASCADE County in the City of CASCADE

Location: MALMSTROM AFB I 6
INTERSTATE 15
CASCADE, MT 59421 CASCADE

Sys Fac ID: 07-09068

Last Inspected On: 9/8/2015

Operating Permit Renewal Date: 9/22/2018

Contact: Jim Hodges,

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536
Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	23	5/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
130		6/13/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in CASCADE County in the City of FORT SHAW

Location: MALMSTROM AFB H 6
MT HIGHWAY 21
FORT SHAW, MT 59443 CASCADE

Sys Fac ID: 07-09057

Last Inspected On: 9/17/2015

Operating Permit Renewal Date: 9/22/2018

Contact: Jim Hodges,

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536
Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	24	9/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
123		6/10/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in CASCADE County in the City of FORT SHAW

Location: MALMSTROM AFB I 9
MT HIGHWAY 21
FORT SHAW, MT 59443 CASCADE

Sys Fac ID: 07-09071

Last Inspected On: 9/21/2015

Operating Permit Renewal Date: 9/22/2018

Contact: Jim Hodges,

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536
Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	24	10/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
132		6/12/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in CASCADE County in the City of FORT SHAW

Location: MALMSTROM AFB I 08
MT HIGHWAY 21
FORT SHAW, MT 59443 CASCADE

Sys Fac ID: 07-10840

Last Inspected On: 9/21/2015

Operating Permit Renewal Date: 9/22/2018

Contact: Jim Hodges,

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
William Hoffmeister, UST Class B Operator
Kyle Topp, UST Class B Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	26	9/26/1989	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
152		6/13/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: MOUNTAIN VIEW COOP GREAT FALLS
1000 SMELTER AVE NW
GREAT FALLS, MT 59404 CASCADE

Sys Fac ID: 07-00004

Last Inspected On: 7/11/2013

Operating Permit Renewal Date: 8/4/2016

Contact: Dan Morana, (406) 453-2435

Owners/Operators: Mountain View Coop, Owner

(406)-453-2435

ATTN DAVE DOUGLAS
2200 OLD HAVRE HWY
BLACK EAGLE MT 59414-1043

David Douglas, UST Class A Operator
Gary Boysun, UST Class B Operator
John Malley, UST Class B Operator
Jasmin Nguyen, UST Class B Operator
David Douglas, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	20	11/1/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1012			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
12,000					
2	20	11/1/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1013			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
12,000					
3	20	11/1/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1014			None	None	Yes
Temporarily Out of Use			Electronic Line Leak Detector	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
12,000					
11	20	11/1/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1009			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
12,000					

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: MOUNTAIN VIEW COOP GREAT FALLS
1000 SMELTER AVE NW
GREAT FALLS, MT 59404 CASCADE

Sys Fac ID: 07-00004
Last Inspected On: 7/11/2013
Operating Permit Renewal Date: 8/4/2016

Contact: Dan Morana, (406) 453-2435

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
12	20	11/1/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1010			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
12,000					
13	20	11/1/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1011			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
12,000					

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: BISON FORD
500 10TH AVE S
GREAT FALLS, MT 59405 CASCADE
Contact: Steve Buckmiller, (406) 731-5264

Sys Fac ID: 07-00077
Last Inspected On: 12/15/2015
Operating Permit Renewal Date: 4/30/2019

Owners/Operators: Bison Motors, Owner (406)-727-2552 500 10TH AVE S
GREAT FALLS MT 59405-4085
RYAN CHRISTENSEN, UST Class A Operator
RYAN CHRISTENSEN, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
7	27	8/5/1988	Fiberglass Reinforced Plastic	Flexible Plastic	
3908		4/10/2013	None	Double-Walled	Yes
Currently in Use			Not Required	U.S. Suction	Not Applicable
Waste Oil			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
3,000		4/10/2013	Other , Other		
8	27	8/5/1988	Fiberglass Reinforced Plastic	Flexible Plastic	
4303		4/10/2013	None	Double-Walled	Yes
Currently in Use			Not Required	U.S. Suction	Not Applicable
Waste Oil			Manual Tank Gauging	MLLD Line Tightness Testing	
1,000		4/10/2013			

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: GENERAL DISTRIBUTING CO INC
430 17TH AVE NE
GREAT FALLS, MT 59404 CASCADE

Sys Fac ID: 07-00081

Last Inspected On: 3/28/2014

Operating Permit Renewal Date: 8/5/2017

Contact: Ramona Ehnes, (406) 454-1351

Owners/Operators: General Distributing Co Inc, Owner (406)-454-1351 PO BOX 2606
GREAT FALLS MT 59403-2606

Jake Schrock, UST Class A Operator
Aaron Timmons, UST Class A Operator
Jake Schrock, UST Class B Operator
Aaron Timmons, UST Class B Operator
Aaron Timmons, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	38	2/14/1978	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
1206			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Stat. Inventory Reconciliation	Deferred	
2,000					
2	38	2/14/1978	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
1207			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Stat. Inventory Reconciliation	Deferred	
4,000					
3	38	2/14/1978	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
1208			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel			Stat. Inventory Reconciliation	Deferred	
6,000					

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: NOONS 574
1300 12TH AVE S
GREAT FALLS, MT 59405 CASCADE

Sys Fac ID: 07-00082

Last Inspected On: 3/20/2015

Operating Permit Renewal Date: 5/29/2018

Contact: Harinder Singh, (406) 452-2471

Owners/Operators: Singh Inc, Owner

(406)-868-2062

ATTN HARINDER SINGH
PO BOX 7208
GREAT FALLS MT 59406-7208

H & R Inc, Operator

(406)-868-2062

3601 10TH AVE S
GREAT FALLS MT 59405-3449

Harinder Singh, UST Class A Operator

Rajinder Singh, UST Class A Operator

Frank Kruse, UST Class B Operator

Frank Kruse, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	04	11/1/2011	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5339			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		9/13/2010	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		9/13/2010	Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	Yes
4	04	11/1/2011	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5340			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		9/13/2010	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		9/13/2010	Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	Yes

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: NOON'S 572
5600 3RD AVE S
GREAT FALLS, MT 59405 CASCADE
Contact: H & R, INC, (406) 452-1041

Sys Fac ID: 07-00090
Last Inspected On: 12/5/2013
Operating Permit Renewal Date: 3/14/2017

Owners/Operators: Singh Inc, Owner (406)-868-2062 ATTN HARINDER SINGH
PO BOX 7208
GREAT FALLS MT 59406-7208
H & R Inc, Operator (406)-868-2062 3601 10TH AVE S
GREAT FALLS MT 59405-3449
Harinder Singh, UST Class A Operator
Rajinder Singh, UST Class A Operator
Frank Kruse, UST Class B Operator
Frank Kruse, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	45	12/31/1970	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4439			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		9/11/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	45	12/31/1970	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
3838			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		9/11/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: NOONS 571
3200 10TH AVE S
GREAT FALLS, MT 59405 CASCADE

Sys Fac ID: 07-00092
Last Inspected On: 7/8/2013
Operating Permit Renewal Date: 11/20/2016

Contact: Harinder Singh, (406) 452-1041

Owners/Operators: Singh Inc, Owner H & R Inc, Operator Harinder Singh, UST Class A Operator Rajinder Singh, UST Class A Operator Frank Kruse, UST Class B Operator Frank Kruse, UST Class B Global Operator	(406)-868-2062 (406)-868-2062	ATTN HARINDER SINGH PO BOX 7208 GREAT FALLS MT 59406-7208 3601 10TH AVE S GREAT FALLS MT 59405-3449
---	--	---

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	45	12/31/1970	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3839			Lined Interior/Impressed Current	None	Yes
Currently in Use		12/21/2008	Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		9/13/2010	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000		6/15/2013			
2	45	12/31/1970	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3840			Lined Interior/Impressed Current	None	Yes
Currently in Use		12/21/2008	Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		9/13/2010	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000		6/15/2013			
3	45	12/31/1970	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4440			Lined Interior/Impressed Current	None	Yes
Currently in Use		12/21/2008	Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		9/13/2010	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000		6/15/2013			

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: GAS N SHOP 2
101 TRUMAN AVE
GREAT FALLS, MT 59404 CASCADE
Contact: Kevin Joyce, (406) 965-2336

Sys Fac ID: 07-00097
Last Inspected On: 12/10/2014
Operating Permit Renewal Date: 3/13/2018

Owners/Operators: Sandeep Muhar, Owner (406)-624-6912 1001 34TH AVE NE
GREAT FALLS MT 59404
Perry Joyce, UST Class A Operator
Gurinderbir Muhar, UST Class A Operator
Maureen Pettis, UST Class B Operator
Kevin Joyce, UST Class B Global Operator
Gurinderbir Muhar, UST Class B Global Operator
Sandeep Muhar, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	25	3/4/1990	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3546			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		2/14/2005	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
10,000					
3	25	3/4/1990	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3547			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		2/14/2005	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
10,000					
4	25	3/4/1990	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3545			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		2/14/2005	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
10,000					

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: CARL'S AUTOCARE INC
2300 10TH AVE S
GREAT FALLS, MT 59405 CASCADE

Sys Fac ID: 07-00621

Last Inspected On: 9/23/2014

Operating Permit Renewal Date: 3/18/2018

Contact: Carl Halcro, (406) 761-1342

Owners/Operators: Carl Halcro, Owner (406)-761-1342 2300 10TH AVE S
GREAT FALLS MT 59405-2968
Carl Halcro, UST Class A Operator
Paul Halcro, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
5	30	1/27/1986	Steel Clad	Fiberglass Reinforced Plastic	Ball Float Valve
1264			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		9/23/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		3/24/2014	TLS-250 , Veeder Root		
6	30	1/27/1986	Steel Clad	Fiberglass Reinforced Plastic	Ball Float Valve
1265			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		9/23/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		3/24/2014	TLS-250 , Veeder Root		
7	30	1/27/1986	Steel Clad	Fiberglass Reinforced Plastic	Ball Float Valve
1266			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		9/23/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		3/24/2014	TLS-250 , Veeder Root		

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: GREAT FALLS FIRE STATION 1 GREAT FALLS
105 9TH ST S
GREAT FALLS, MT 59401 CASCADE

Sys Fac ID: 07-00680

Last Inspected On: 5/6/2013

Operating Permit Renewal Date: 9/18/2016

Contact: Dale Clavert, (406) 781-8993

Owners/Operators: City of Great Falls, Owner (406)-771-1180 3015 AIRPORT LANE
GREAT FALLS MT 59404-5021
Doug Alm, UST Class A Operator
Dale Calvert, UST Class A Operator
Doug Alm, UST Class B Global Operator
Dale Calvert, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	24	4/22/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
636			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Not Listed	Not Applicable
Diesel		7/30/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
2,086		3/26/2013	TLS-450 , Veeder Root		
2	24	4/22/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
637			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Not Listed	Not Applicable
Diesel		7/30/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
2,086		3/26/2013	TLS-450 , Veeder Root		
3	24	4/22/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
638			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Not Listed	Not Applicable
Gasoline		7/30/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		3/26/2013	TLS-450 , Veeder Root		

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: ZIP TRIP 45
625 1ST AVE N
GREAT FALLS, MT 59401 CASCADE
Contact: Mike Baumgartner, (406) 761-2175

Sys Fac ID: 07-01057
Last Inspected On: 1/21/2016
Operating Permit Renewal Date: 3/30/2019

Owners/Operators: CHS Inc - Spokane Valley, Owner (509)-535-7701 16124 E MARIETTA LANE
SPOKANE VALLEY WA 99216
Cenex Zip Trip, Operator (509)-535-7701 16124 E MARIETTA LANE
SPOKANE VALLEY WA 99216
Sean Hurley, UST Class A Operator
Luci Tuttle, UST Class B Operator
Karina Serrano, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	33	4/27/1982	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
1610			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		7/13/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	33	4/27/1982	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
1611			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		7/13/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	33	4/27/1982	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
1612			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		7/13/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: RAINBOW SHOP
6700 RAINBOW DAM ROAD
GREAT FALLS, MT 59404 CASCADE
Contact: Beth Stimatz, (406) 497-2687

Sys Fac ID: 07-01189
Last Inspected On: 7/18/2014
Operating Permit Renewal Date: 8/5/2017

Owners/Operators: Northwestern Energy, Owner/Operator (406)-497-3382 ATTN: BETH STIMATZ
40 E BROADWAY ST
BUTTE MT 59701-9394

Scott Cleveland, UST Class A Operator
Michael Holzwarth, UST Class A Operator
Scott Cleveland, UST Class B Operator
Zane Shaulis, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	23	8/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1674			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel		6/12/2014	Automatic Tank Gauging 0.2	Deferred	
550			Gilbarco EMC Basic , Gilbarco		
2	23	8/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1675			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline		6/12/2014	Automatic Tank Gauging 0.2	Deferred	
2,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: BLACK EAGLE SERVICE CENTER
1501 N RIVER RD
GREAT FALLS, MT 59403 CASCADE

Sys Fac ID: 07-01190

Last Inspected On: 11/25/2013

Operating Permit Renewal Date: 1/28/2017

Contact: Beth Stimatz, (406) 497-2687

Owners/Operators: Northwestern Energy, Owner (406)-497-3382 ATTN: BETH STIMATZ
40 E BROADWAY ST
BUTTE MT 59701-9394

John Habeger, UST Class A Operator

Charles Roth, UST Class B Operator

Michael Broderick, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	24	12/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1676			None	none	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Deferred	
2,086					
2	24	12/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1677			None	none	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Deferred	
2,086					

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: KEITHS COUNTY STORE
1621 10TH AVE S
GREAT FALLS, MT 59405 CASCADE
Contact: David Keith, (406) 727-7114

Sys Fac ID: 07-01418
Last Inspected On: 7/2/2014
Operating Permit Renewal Date: 12/2/2017

Owners/Operators: Keith's Country Store, Owner (406)-727-7114 1621 10TH AVE S
GREAT FALLS MT 59405
David Keith, Operator (406)-862-2578 933 4TH ST
WHITEFISH MT 59937-2707
David Keith, UST Class A Operator
Theresa Keith, UST Class A Operator
Anna Dion, UST Class B Operator
David Keith, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	16	4/1/1999	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
3988			None	None	Yes
Currently in Use		4/1/2009	Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
6,000		4/27/2011	TLS-350/Gilbarco EMC , Veeder Root		
4	16	4/1/1999	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
3989			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000		4/27/2011	TLS-350/Gilbarco EMC , Veeder Root		
5	16	4/1/1999	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
3990			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
12,000		4/27/2011	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: PHILLIPS 66 GREAT FALLS TERMINAL
1401 52ND ST N
GREAT FALLS, MT 59405 CASCADE

Sys Fac ID: 07-01845

Last Inspected On: 4/8/2013

Operating Permit Renewal Date: 6/9/2016

Contact: Mark Becker, (406) 441-4747

Owners/Operators: Phillips 66 Great Falls Terminal, Owner	(406)-255-5714	2626 LILLIAN AVENUE BILLINGS MT 59101
Phillips 66 Pipeline LLC, Operator	(406)-255-5714	2626 LILLIAN AVENUE BILLINGS MT 59101
Brian Buckley, UST Class A Operator		
Ryan Norwood, UST Class A Operator		
John Stampfli, UST Class A Operator		
Steve Thomas, UST Class A Operator		
Earl Anderson, UST Class B Operator		
Brian Buckley, UST Class B Operator		
Theodore Hagemo, UST Class B Operator		
Ryan Norwood, UST Class B Operator		
Scott Parker, UST Class B Operator		
Clifford Pearce, UST Class B Operator		
Gail Pierce, UST Class B Operator		
Steven Sheldon, UST Class B Operator		
Steve Thomas, UST Class B Operator		
Michael Crawford, UST Class B Global Operator		
James Olson, UST Class B Global Operator		
John Stampfli, UST Class B Global Operator		
Dane Whittaker, UST Class B Global Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	56	1/1/1960	Unknown	Steel	
707	Yes		None	None	Yes
Currently in Use			Not Required	Pressurized	Not Applicable, Impressed Current
Diesel		6/12/2012	Deferred	MLLD Line Tightness Testing	
1,512,000		10/18/2012			

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: PHILLIPS 66 GREAT FALLS TERMINAL
1401 52ND ST N
GREAT FALLS, MT 59405 CASCADE
Contact: Mark Becker, (406) 441-4747

Sys Fac ID: 07-01845
Last Inspected On: 4/8/2013
Operating Permit Renewal Date: 6/9/2016

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
5	56	1/1/1960	Unknown	Steel - Terminal Piping	
704	Yes		None	None	Yes
Currently in Use			Not Required	Pressurized	Not Applicable, Impressed Current
Gasoline		6/12/2012	Deferred	MLLD Line Tightness Testing	
2,520,000		11/29/2012			
11	56	1/1/1960	Unknown	Steel	
714	Yes		None	None	Yes
Currently in Use			Not Required	Pressurized	Not Applicable, Impressed Current
Gasoline		6/12/2012	Deferred	MLLD Line Tightness Testing	
1,512,000		11/30/2012			
14	56	1/1/1960	Unknown	Steel	
713	Yes		None	None	Yes
Temporarily Out of Use			Not Required	Pressurized	Not Applicable, Impressed Current
Kerosene		6/12/2012	Deferred	MLLD Line Tightness Testing	
21,000		11/3/2009			
17	56	1/1/1960	Unknown	Steel - Terminal Piping	
711	Yes		None	None	Yes
Currently in Use			Not Required	Pressurized	Not Applicable, Impressed Current
Diesel		6/12/2012	Deferred	MLLD Line Tightness Testing	
1,050,000		10/18/2012			
18	56	1/1/1960	Unknown	Steel - Terminal Piping	
709	Yes		None	None	Yes
Currently in Use			Not Required	Pressurized	Not Applicable, Impressed Current
Kerosene		6/12/2012	Deferred	MLLD Line Tightness Testing	
1,512,000		10/18/2012			

Location:	GREAT FALLS SINCLAIR 620 57TH ST S GREAT FALLS, MT 59405	CASCADE	Sys Fac ID: 07-02087 Last Inspected On: 1/19/2015 Operating Permit Renewal Date: 2/26/2018
------------------	--	---------	---

Owners/Operators:	Set Five LLC, Owner	(719)-510-8778	PO BOX 827 HARLOWTON MT 59036
	Great Falls Sinclair, Operator	(406)-727-5746	620 57TH ST S GREAT FALLS MT 59405-3940
	Greg Haines, UST Class A Operator		
	Roberta Gresham, UST Class B Operator		
	Greg Haines, UST Class B Operator		
	Norm Jensen, UST Class B Operator		
	Mitzi McIntosh, UST Class B Operator		
	NayOmie Bean, UST Class B Global Operator		
	Thomas O'Hagan, UST Class B Global Operator		
	Derek Richardson, UST Class B Global Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	37	4/4/1978	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
1933			Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Diesel		1/19/2015	Automatic Tank Gauging 0.1, Stat. Inventory Reconciliation	MLLD Line Tightness Testing	
8,000		9/3/2014	Gilbarco EMC Basic , Gilbarco		
2	37	4/4/1978	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
1934			Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		1/19/2015	Automatic Tank Gauging 0.1, Stat. Inventory Reconciliation	MLLD Line Tightness Testing	
8,000		9/3/2014	Gilbarco EMC Basic , Gilbarco		

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: GREAT FALLS SINCLAIR
620 57TH ST S
GREAT FALLS, MT 59405 CASCADE

Sys Fac ID: 07-02087

Last Inspected On: 1/19/2015

Operating Permit Renewal Date: 2/26/2018

Contact: Greg Hanes, (406) 727-5746

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	37	4/4/1978	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
1935			Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		1/19/2015	Automatic Tank Gauging 0.1, Stat. Inventory	MLLD Line Tightness Testing	
			Reconciliation		
12,000		9/3/2014	Gilbarco EMC Basic , Gilbarco		

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: MONTANA AIR NATIONAL GUARD UST
2800 AIRPORT AVENUE B
GREAT FALLS, MT 59404 CASCADE

Sys Fac ID: 07-02294

Last Inspected On: 11/6/2013

Operating Permit Renewal Date: 3/11/2017

Contact: Robert Tester, (406) 791-0316

Owners/Operators: Montana Air National Guard, Owner (406)-791-6330 2800 AIRPORT AVENUE B
GREAT FALLS MT 59404-5570

Robin T Atkison, UST Class A Operator
Briana Boggio, UST Class A Operator
Cassie Clark, UST Class A Operator
Ted Clark, UST Class A Operator
Danny Collins, UST Class A Operator
Joe Kerkes, UST Class A Operator
Scott Kohles, UST Class A Operator
Joseph Leggett, UST Class A Operator
James Robertson, UST Class A Operator
Briana Boggio, UST Class B Operator
Cassie Clark, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	61	1/1/1955	Bare Steel	No Piping	High Level Alarm
4783			Lined Interior/Impressed Current	None	Yes
Currently in Use			Not Required	Gravity Feed	Impressed Current
Jet Fuel		6/26/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2		
25,000					
3	61	1/1/1955	Bare Steel	No Piping	High Level Alarm
1667			Lined Interior/Impressed Current	None	Yes
Currently in Use			Not Required	Gravity Feed	Impressed Current
Jet Fuel		6/26/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2		
25,000					

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: MONTANA AIR NATIONAL GUARD UST
2800 AIRPORT AVENUE B
GREAT FALLS, MT 59404 CASCADE

Sys Fac ID: 07-02294
Last Inspected On: 11/6/2013
Operating Permit Renewal Date: 3/11/2017

Contact: Robert Tester, (406) 791-0316

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	61	1/1/1955	Bare Steel	No Piping	High Level Alarm
1665			Lined Interior/Impressed Current	None	Yes
Currently in Use			Not Required	Gravity Feed	Impressed Current
Jet Fuel		6/26/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2		
25,000					
5	61	1/1/1955	Bare Steel	No Piping	High Level Alarm
1664			Lined Interior/Impressed Current	None	Yes
Currently in Use			Not Required	Gravity Feed	Impressed Current
Jet Fuel		6/26/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2		
25,000					
6	61	1/1/1955	Bare Steel	No Piping	High Level Alarm
1663			Lined Interior/Impressed Current	None	Yes
Currently in Use			Not Required	Gravity Feed	Impressed Current
Jet Fuel		6/26/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2		
25,000					
7	61	1/1/1955	Bare Steel	No Piping	High Level Alarm
1662			Lined Interior/Impressed Current	None	Yes
Currently in Use			Not Required	Gravity Feed	Impressed Current
Jet Fuel		6/26/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2		
25,000					
18	21	10/1/1994	Fiberglass Reinforced Plastic	No Piping	
			Double-Walled	None	Yes
Currently in Use				Not Listed	Not Applicable
Oil/Water Separator		9/19/2007	Continuous Interstitial Monitor, Deferred		
500					

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: MONTANA AIR NATIONAL GUARD UST
2800 AIRPORT AVENUE B
GREAT FALLS, MT 59404 CASCADE

Sys Fac ID: 07-02294
Last Inspected On: 11/6/2013
Operating Permit Renewal Date: 3/11/2017

Contact: Robert Tester, (406) 791-0316

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
19	21	10/1/1994	Fiberglass Reinforced Plastic Double-Walled	No Piping None	Yes
Currently in Use				Gravity Feed	Not Applicable
Oil/Water Separator		9/19/2007	Continuous Interstitial Monitor, Deferred		
500					
20	21	10/1/1994	Fiberglass Reinforced Plastic Double-Walled	No Piping None	Yes
Currently in Use				Gravity Feed	Not Applicable
Oil/Water Separator		9/19/2007	Continuous Interstitial Monitor, Deferred		
500					
21	21	10/1/1994	Fiberglass Reinforced Plastic Double-Walled	No Piping None	Yes
Currently in Use				Gravity Feed	Not Applicable
Oil/Water Separator		9/19/2007	Continuous Interstitial Monitor		
500					
22			Steel Clad None	No Piping None	Yes
Currently in Use				Gravity Feed	
Oil/Water Separator		9/19/2007	Deferred		
110					

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: FEDERAL AVIATION ADMIN AIRWAY TERMINAL
2830 AIRPORT AVENUE A
GREAT FALLS, MT 59404 CASCADE

Sys Fac ID: 07-02558

Last Inspected On: 1/26/2015

Operating Permit Renewal Date: 3/26/2018

Contact: Joe Konesky, (406) 453-1429

Owners/Operators: Federal Aviation Admin Great Falls, Owner

(406)-788-8041

2830 AIRPORT AVENUE A
GREAT FALLS MT 59404-5544

Joe Konesky, UST Class A Operator

Joe Konesky, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	18	7/31/1997	Unknown	Flexible Plastic	
1048	Yes	5/7/2012	None	Double-Walled	Yes
Currently in Use		7/31/2007	Not Required	U.S. Suction	Not Applicable
Diesel			Deferred	MLLD Line Tightness Testing	
1,500			Other , Other	Continuous Interstitial Monitor	

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: TOWN PUMP INC GREAT FALLS 4
700 10TH AVE S
GREAT FALLS, MT 59405 CASCADE

Sys Fac ID: 07-03217

Last Inspected On: 4/5/2013

Operating Permit Renewal Date: 8/13/2016

Contact: Trent Biggers, (406) 497-6700

Owners/Operators: Billings Holdings LLC, Owner (406)-497-6700 PO BOX 6000
BUTTE MT 59702-6000
Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	20	8/1/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4805			None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000					
2	20	8/1/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4806			None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000					
3	20	8/1/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4804			None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
2,000					
8	13	8/18/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4708			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
10,000					

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: TOWN PUMP INC GREAT FALLS 4
700 10TH AVE S
GREAT FALLS, MT 59405 CASCADE

Sys Fac ID: 07-03217

Last Inspected On: 4/5/2013

Operating Permit Renewal Date: 8/13/2016

Contact: Trent Biggers, (406) 497-6700

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
9	13	8/18/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4709			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
5,000					

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: BENEFIS HEALTH CARE WEST CAMPUS
500 15TH AVE S
GREAT FALLS, MT 59405 CASCADE

Sys Fac ID: 07-03298

Last Inspected On: 9/22/2014

Operating Permit Renewal Date: 1/29/2018

Contact: Walt Williams, (406) 455-2512

Owners/Operators: Benefis Health Care, Owner

(406)-455-5135

ATTN MIKE BATTLESON MAINTENANCE
PO BOX 5013
GREAT FALLS MT 59403-5013

Mike Battleson, UST Class A Operator
Louis D'Antuono, UST Class A Operator
Mike Battleson, UST Class B Operator
Louis D'Antuono, UST Class B Operator
Kim Frank, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
5	19	7/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
3401		9/22/2014	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.1	Continuous Interstitial Monitor	
2,000			EECO 1500 , EMCO Electronics		
6	16	5/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
4003		9/22/2014	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.1	Continuous Interstitial Monitor	
15,000			EECO 1500 , EMCO Electronics		

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: TOWN PUMP INC GREAT FALLS 5
3700 31ST ST SW SUITE 1
GREAT FALLS, MT 59404 CASCADE

Sys Fac ID: 07-03463

Last Inspected On: 4/5/2013

Operating Permit Renewal Date: 8/13/2016

Contact: Trent Biggers, (406) 497-6700

Owners/Operators: Great Falls Holdings LLC, Owner (406)-497-6700 PO BOX 6000
BUTTE MT 59702-6000
Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	27	1/15/1989	Steel Clad	Fiberglass Reinforced Plastic	Ball Float Valve
2223			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		4/4/2013	Automatic Tank Gauging 0.2, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
6,000					
6	27	1/15/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
2224			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		4/4/2013	Automatic Tank Gauging 0.2, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
14,000					
7	22	4/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
2225			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		4/4/2013	Automatic Tank Gauging 0.2, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Yes
10,000					
8	22	4/1/1993	Bare Steel	Fiberglass Reinforced Plastic	Ball Float Valve
2226			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		4/4/2013	Automatic Tank Gauging 0.2, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
6,000					

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: TOWN PUMP INC GREAT FALLS 5
3700 31ST ST SW SUITE 1
GREAT FALLS, MT 59404 CASCADE

Sys Fac ID: 07-03463

Last Inspected On: 4/5/2013

Operating Permit Renewal Date: 8/13/2016

Contact: Trent Biggers, (406) 497-6700

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
9	22	4/1/1993	Bare Steel	Fiberglass Reinforced Plastic	Ball Float Valve
2227			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		4/4/2013	Automatic Tank Gauging 0.2, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
6,000					
11	09	4/25/2006	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5080			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		3/12/2010	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
30,000					
12	09	4/26/2006	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5081			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		3/12/2010	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
30,000					
13	09	4/25/2006	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5082			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		3/12/2010	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
30,000					

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: MINI MART 765
3726 2ND AVE N
GREAT FALLS, MT 59401 CASCADE
Contact: (406) 727-7917

Sys Fac ID: 07-03920
Last Inspected On: 7/26/2013
Operating Permit Renewal Date: 8/13/2016

Owners/Operators: Mini Mart Inc Pueblo, Owner (719)-948-3071 442 KEELER PKWY
PUEBLO CO 81001-4813

Randal Liebnow, UST Class A Operator
John Sumowski, UST Class A Operator
Derrick Trimble, UST Class A Operator
Anthony Mosmiller, UST Class B Operator
Timothy Osterman, UST Class B Operator
Stevie Ulstad, UST Class B Operator
JENNIFER COLEMAN, UST Class B Global Operator
Dustin Harpster, UST Class B Global Operator
Randal Liebnow, UST Class B Global Operator
Anthony Mosmiller, UST Class B Global Operator
Toni Mullen, UST Class B Global Operator
Hiede Richardson, UST Class B Global Operator
Derrick Trimble, UST Class B Global Operator
Stevie Ulstad, UST Class B Global Operator
DeWayne Young, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	31	3/24/1984	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1624			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/18/2010	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
12,000					
2	31	3/24/1984	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1625			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/18/2010	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
12,000					

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: MINI MART 765
 3726 2ND AVE N
 GREAT FALLS, MT 59401 CASCADE
Contact: (406) 727-7917

Sys Fac ID: 07-03920
Last Inspected On: 7/26/2013
Operating Permit Renewal Date: 8/13/2016

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	31	3/24/1984	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1626			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/18/2010	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
12,000					

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: H&R Inc #5
3601 10TH AVE S
GREAT FALLS, MT 59405 CASCADE

Sys Fac ID: 07-03973

Last Inspected On: 12/9/2014

Operating Permit Renewal Date: 3/27/2018

Contact: Harinder Singh, (406) 868-2062

Owners/Operators: Singh Inc, Owner	(406)-868-2062	ATTN HARINDER SINGH PO BOX 7208 GREAT FALLS MT 59406-7208
H & R Inc, Operator	(406)-868-2062	3601 10TH AVE S GREAT FALLS MT 59405-3449
Harinder Singh, UST Class A Operator		
Rajinder Singh, UST Class A Operator		
Frank Kruse, UST Class B Operator		
Frank Kruse, UST Class B Global Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
6	24	6/1/1991	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
1248			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		6/22/2011			
7	24	6/1/1991	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
1249			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		5/18/2011			
8	24	6/1/1991	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
1250			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		5/18/2011			

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: MDOT 31 0701 GREAT FALLS
200 SMELTER AVE NE
GREAT FALLS, MT 59404 CASCADE
Contact: Joe Radonich, (406) 444-9204

Sys Fac ID: 07-04047
Last Inspected On: 12/9/2014
Operating Permit Renewal Date: 3/25/2018

Owners/Operators: MDOT Helena, Owner (406)-444-6200 KIM JANZEN
PO BOX 201001
HELENA MT 59620-1001

Joseph J Radonich, Operator (406)-444-9204 MDT
DEADHEAD
HELENA MT 59620-0901

Jeff Gleason, UST Class A Operator
Brittany Hrgich, UST Class A Operator
Walt Kerttula, UST Class A Operator
James Lamm, UST Class A Operator
Mike Murolo, UST Class A Operator
Joe Radonich, UST Class A Operator
Brian Boettcher, UST Class B Operator
Lucas Cowan, UST Class B Operator
Mark Goldstein, UST Class B Operator
James Lamm, UST Class B Operator
Victor Scott, UST Class B Operator
Brittany Hrgich, UST Class B Global Operator
Joe Radonich, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
5	25	11/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3704			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		12/9/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
12,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: MDOT 31 0701 GREAT FALLS
200 SMELTER AVE NE
GREAT FALLS, MT 59404 CASCADE

Sys Fac ID: 07-04047

Last Inspected On: 12/9/2014

Operating Permit Renewal Date: 3/25/2018

Contact: Joe Radonich, (406) 444-9204

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
6	23	4/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3705			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		12/9/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
12,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: KERNAGHANS SERVICE 8TH AVE N
1507 8TH AVE N
GREAT FALLS, MT 59401 CASCADE

Sys Fac ID: 07-04508

Last Inspected On: 5/8/2013

Operating Permit Renewal Date: 10/26/2016

Contact: Bob Burns, (406) 452-9505

Owners/Operators: James Kernaghan, Owner (406)-452-9505 PO BOX 1711
GREAT FALLS MT 59403-1711
Jeff Rearden, UST Class A Operator
Dennis Albrecht, UST Class B Operator
Bob Burns, UST Class B Operator
Steve Monaco, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	26	7/28/1989	Steel Clad	Fiberglass Reinforced Plastic	High Level Alarm
1473			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
7,500					
4	26	7/28/1989	Steel Clad	Fiberglass Reinforced Plastic	High Level Alarm
1474			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
5,000					
5	26	7/28/1989	Steel Clad	Fiberglass Reinforced Plastic	High Level Alarm
1475			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
7,500					

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: KERNAGHANS SERVICE 8TH AVE N
1507 8TH AVE N
GREAT FALLS, MT 59401 CASCADE
Contact: Bob Burns, (406) 452-9505

Sys Fac ID: 07-04508
Last Inspected On: 5/8/2013
Operating Permit Renewal Date: 10/26/2016

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
6	26	7/28/1989	Steel Clad	Fiberglass Reinforced Plastic	High Level Alarm
1476			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000					
7	26	7/28/1989	Steel Clad	Fiberglass Reinforced Plastic	High Level Alarm
1477			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
4,000					
8	26	7/28/1989	Steel Clad	Fiberglass Reinforced Plastic	High Level Alarm
1478			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000					
9	33	7/29/1982	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1479			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
2,500					

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: KERNAGHANS SERVICE 9TH AVE N
1504 9TH AVE N
GREAT FALLS, MT 59401 CASCADE
Contact: (406) 452-9505

Sys Fac ID: 07-04509
Last Inspected On: 8/29/2014
Operating Permit Renewal Date: 9/3/2017

Owners/Operators: James Kernaghan, Owner (406)-452-9505 PO BOX 1711
GREAT FALLS MT 59403-1711
Jeff Rearden, UST Class A Operator
Dennis Albrecht, UST Class B Operator
Bob Burns, UST Class B Operator
Steve Monaco, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
5	17	5/23/1998	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
1480			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		9/3/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
2,000			TLS-350/Gilbarco EMC , Veeder Root		
6	17	5/23/1998	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
1481			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		9/3/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
1,000			TLS-350/Gilbarco EMC , Veeder Root		
7	17	5/23/1998	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
1482			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		9/3/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
2,000			TLS-350/Gilbarco EMC , Veeder Root		
8	17	5/23/1998	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
1483			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		9/3/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
3,500			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: KERNAGHANS SERVICE 9TH AVE N
1504 9TH AVE N
GREAT FALLS, MT 59401 CASCADE

Sys Fac ID: 07-04509

Last Inspected On: 8/29/2014

Operating Permit Renewal Date: 9/3/2017

Contact: (406) 452-9505

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
9	17	5/23/1998	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
1484			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		9/3/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
1,500			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: TOLAN DISTRIBUTING INC
2201 VAUGHN RD
GREAT FALLS, MT 59404 CASCADE

Sys Fac ID: 07-04511

Last Inspected On: 5/28/2014

Operating Permit Renewal Date: 9/15/2017

Contact: Darron Tolan, (406) 453-8810

Owners/Operators: Tolan Distributing Inc, Owner (406)-453-8810 PO BOX 2923
GREAT FALLS MT 59403-2923
Derrick Tolan, UST Class A Operator
Derrick Tolan, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
6	16	9/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4098		9/28/2012	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
8,000			EECO 1500 , EMCO Electronics		
7	16	9/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4099		9/28/2012	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
4,000			EECO 1500 , EMCO Electronics		
8	16	9/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4100		9/28/2012	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
8,000			EECO 1500 , EMCO Electronics		
9	16	9/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4101		9/28/2012	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
4,000			EECO 1500 , EMCO Electronics		

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: ZIP TRIP 44
1608 FOX FARM RD
GREAT FALLS, MT 59404 CASCADE
Contact: (406) 761-6421

Sys Fac ID: 07-04945
Last Inspected On: 3/14/2014
Operating Permit Renewal Date: 9/3/2017

Owners/Operators: CHS Inc - Spokane Valley, Owner (509)-535-7701 16124 E MARIETTA LANE
SPOKANE VALLEY WA 99216
Cenex Zip Trip, Operator (509)-535-7701 16124 E MARIETTA LANE
SPOKANE VALLEY WA 99216
Tom Savas, UST Class A Operator
Luci Tuttle, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	48	1/1/1968	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1972			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000		3/19/2008	TLS-350/Gilbarco EMC , Veeder Root		
3	48	1/1/1968	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1973			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000		3/19/2008	TLS-350/Gilbarco EMC , Veeder Root		
5	18	11/3/1997	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1974			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
4,000		3/19/2008	TLS-350/Gilbarco EMC , Veeder Root		
6	18	11/1/1997	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1975			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000		3/19/2008	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: GREAT FALLS TRANSIT DISTRICT
3905 N STAR BLVD PO BOX 2353
GREAT FALLS, MT 59405 CASCADE

Sys Fac ID: 07-05346

Last Inspected On: 2/6/2013

Operating Permit Renewal Date: 6/2/2016

Contact: Jim Hegleson, (406) 727-0382

Owners/Operators: Great Falls Transit District, Owner (406)-727-0382 PO BOX 2353
GREAT FALLS MT 59403-2353

James Helgeson, UST Class A Operator
Jack Hoffman, UST Class A Operator
James Helgeson, UST Class B Operator
Jack Hoffman, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	30	5/6/1985	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1233			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
12,380		2/21/2007			
2	30	5/6/1985	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1234			None	None	Yes
Currently in Use			Not Required	Gravity Feed	Not Applicable
Waste Oil			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
1,000		5/13/2013			

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: CITY SHOP COMPLEX
1025 25TH AVE NE
GREAT FALLS, MT 59404 CASCADE
Contact: Doug Alm, (406) 781-8993

Sys Fac ID: 07-05558
Last Inspected On: 5/6/2013
Operating Permit Renewal Date: 8/11/2016

Owners/Operators: City of Great Falls, Owner (406)-771-1180 3015 AIRPORT LANE
GREAT FALLS MT 59404-5021
Doug Alm, UST Class A Operator
Dale Calvert, UST Class A Operator
Doug Alm, UST Class B Global Operator
Dale Calvert, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
6	26	2/23/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
640			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel		7/30/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		3/18/2013	TLS-450 , Veeder Root		
7	26	2/23/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
641			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline		7/30/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		3/18/2013	TLS-450 , Veeder Root		
8	26	2/23/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
642			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline		7/30/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		3/18/2013	TLS-450 , Veeder Root		

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: Mini Mart 766
900 1ST AVE N
GREAT FALLS, MT 59401 CASCADE
Contact: (406) 761-8723

Sys Fac ID: 07-05775
Last Inspected On: 7/26/2013
Operating Permit Renewal Date: 8/13/2016

Owners/Operators: Mini Mart Inc Pueblo, Owner (719)-948-3071 442 KEELER PKWY
PUEBLO CO 81001-4813

Randal Liebnow, UST Class A Operator
John Sumowski, UST Class A Operator
Derrick Trimble, UST Class A Operator
Sarah Mosmiller, UST Class B Operator
Timothy Osterman, UST Class B Operator
Stevie Ulstad, UST Class B Operator
JENNIFER COLEMAN, UST Class B Global Operator
Dustin Harpster, UST Class B Global Operator
Randal Liebnow, UST Class B Global Operator
Anthony Mosmiller, UST Class B Global Operator
Toni Mullen, UST Class B Global Operator
Hiede Richardson, UST Class B Global Operator
Derrick Trimble, UST Class B Global Operator
Stevie Ulstad, UST Class B Global Operator
DeWayne Young, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	32	4/27/1983	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1627			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		7/2/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
8,000					

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: Mini Mart 766
 900 1ST AVE N
 GREAT FALLS, MT 59401 CASCADE
Contact: (406) 761-8723

Sys Fac ID: 07-05775
Last Inspected On: 7/26/2013
Operating Permit Renewal Date: 8/13/2016

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	32	4/27/1983	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1628			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		7/2/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
8,000					
3	32	4/27/1983	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1629			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		7/2/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
8,000					

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: MINI MART 767
601 SMELTER AVE NW
GREAT FALLS, MT 59404 CASCADE

Sys Fac ID: 07-05776

Last Inspected On: 7/26/2013

Operating Permit Renewal Date: 8/6/2016

Contact: Michelle Mckerchie, (406) 727-8578

Owners/Operators: Mini Mart Inc Pueblo, Owner (719)-948-3071 442 KEELER PKWY
PUEBLO CO 81001-4813

Randal Liebnow, UST Class A Operator
John Sumowski, UST Class A Operator
Derrick Trimble, UST Class A Operator
Frank Headley, UST Class B Operator
Timothy Osterman, UST Class B Operator
Stevie Ulstad, UST Class B Operator
JENNIFER COLEMAN, UST Class B Global Operator
Dustin Harpster, UST Class B Global Operator
Randal Liebnow, UST Class B Global Operator
Anthony Mosmiller, UST Class B Global Operator
Toni Mullen, UST Class B Global Operator
Hiede Richardson, UST Class B Global Operator
Derrick Trimble, UST Class B Global Operator
DeWayne Young, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	32	4/27/1983	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
3638			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		7/3/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000					

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: MINI MART 767
601 SMELTER AVE NW
GREAT FALLS, MT 59404 CASCADE

Sys Fac ID: 07-05776
Last Inspected On: 7/26/2013
Operating Permit Renewal Date: 8/6/2016

Contact: Michelle Mckerchie, (406) 727-8578

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	32	4/27/1983	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
3639			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		7/3/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000					
3	32	4/27/1983	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
3640			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		7/3/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000					

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: MINI MART 768
1225 CENTRAL AVE W
GREAT FALLS, MT 59404 CASCADE
Contact: (406) 727-8765

Sys Fac ID: 07-05777
Last Inspected On: 7/26/2013
Operating Permit Renewal Date: 8/6/2016

Owners/Operators: Mini Mart Inc Pueblo, Owner (719)-948-3071 442 KEELER PKWY
PUEBLO CO 81001-4813

Randal Liebnow, UST Class A Operator
John Sumowski, UST Class A Operator
Derrick Trimble, UST Class A Operator
Anthony Mosmiller, UST Class B Operator
Timothy Osterman, UST Class B Operator
Stevie Ulstad, UST Class B Operator
Dustin Harpster, UST Class B Global Operator
Randal Liebnow, UST Class B Global Operator
Anthony Mosmiller, UST Class B Global Operator
Toni Mullen, UST Class B Global Operator
Hiede Richardson, UST Class B Global Operator
Derrick Trimble, UST Class B Global Operator
DeWayne Young, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	43	4/26/1972	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1630			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		7/2/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000		1/7/2011			
2	43	4/26/1972	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1631			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		7/2/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000		1/7/2011			

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: MINI MART 768
 1225 CENTRAL AVE W
 GREAT FALLS, MT 59404 CASCADE
Contact: (406) 727-8765

Sys Fac ID: 07-05777
Last Inspected On: 7/26/2013
Operating Permit Renewal Date: 8/6/2016

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	43	4/26/1972	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1632			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		7/2/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000		1/7/2011			

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: GAS N SHOP
101 SMELTER AVE NW
GREAT FALLS, MT 59404 CASCADE

Sys Fac ID: 07-05851

Last Inspected On: 12/8/2014

Operating Permit Renewal Date: 3/27/2018

Contact: Harinder Singh, (406) 771-0730

Owners/Operators: Muhar LLC, Owner (406)-624-6912 1001 34TH AVE NE
GREAT FALLS MT 59404

Gurinderbir Muhar, UST Class A Operator
Harinder Singh, UST Class A Operator
Frank Kruse, UST Class B Operator
Gurinderbir Muhar, UST Class B Global Operator
Sandeep Muhar, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	27	7/21/1988	Steel Clad	Fiberglass Reinforced Plastic	High Level Alarm
1251			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Approved Remote Monitoring	
4,000		2/28/2006			
2	27	7/21/1988	Steel Clad	Fiberglass Reinforced Plastic	High Level Alarm
1252			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, MLLD Line Tightness Testing	
4,000		2/28/2006			
3	27	7/21/1988	Steel Clad	Fiberglass Reinforced Plastic	High Level Alarm
1253			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, MLLD Line Tightness Testing	
4,000		2/28/2006			

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: BEST OIL DISTRIBUTING INC
5401 RIVER DR N
GREAT FALLS, MT 59405 CASCADE

Sys Fac ID: 07-05852

Last Inspected On: 2/5/2015

Operating Permit Renewal Date: 4/11/2018

Contact: Thomas Schimerowski, (406) 453-0971

Owners/Operators: BEST OIL DISTRIBUTING INC, Owner (406)-453-0971 ATTN THOMAS SCHIMEROWSKI
5401 RIVER DR N
GREAT FALLS MT 59405-1081

Thomas Schimerowski, UST Class A Operator
Jeff Slininger, UST Class A Operator
Brian McNeil, UST Class B Operator
Eddie Parker, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	34	5/1/1981	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1254			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000		6/4/2003	TLS-350/Gilbarco EMC , Veeder Root		
3	34	5/1/1981	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1255			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000		5/3/2002	TLS-350/Gilbarco EMC , Veeder Root		
4	34	5/1/1981	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1256			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000		7/1/2001	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: BEST OIL DISTRIBUTING INC
5401 RIVER DR N
GREAT FALLS, MT 59405 CASCADE
Contact: Thomas Schimerowski, (406) 453-0971

Sys Fac ID: 07-05852
Last Inspected On: 2/5/2015
Operating Permit Renewal Date: 4/11/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
5	34	5/1/1981	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1257			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000		5/29/2003	TLS-350/Gilbarco EMC , Veeder Root		
7	17	4/1/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1258			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		7/20/2001	TLS-350/Gilbarco EMC , Veeder Root		
8	17	4/1/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1259			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		9/24/2004	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: CITY MOTOR CO INC
3900 10TH AVE S
GREAT FALLS, MT 59405 CASCADE

Sys Fac ID: 07-05853

Last Inspected On: 3/24/2014

Operating Permit Renewal Date: 7/1/2017

Contact: Robert H Oakland, (406) 761-4900

Owners/Operators: City Motors, Owner (406)-761-4900 3900 10TH AVE S
GREAT FALLS MT 59405-3695
KEN MYERS, UST Class A Operator
KEN MYERS, UST Class B Operator
Casey O'Neill, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
6	26	9/1/1989	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
2365			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline		3/20/2008	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
3,000		7/2/2014	EECO 1500 , EMCO Electronics		
7	26	9/1/1989	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
2366			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Waste Oil		3/20/2008	Automatic Tank Gauging 0.2	Deferred	
3,000		6/12/2014	EECO 1500 , EMCO Electronics		

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: HALL TRANSIT CO
2620 UPPER RIVER RD
GREAT FALLS, MT 59405 CASCADE

Sys Fac ID: 07-06402

Last Inspected On: 7/31/2014

Operating Permit Renewal Date: 8/6/2017

Contact: Don Hall, (406) 452-0082

Owners/Operators: Hall Transit Co, Owner (406)-452-0082 2620 UPPER RIVER RD
GREAT FALLS MT 59405-7231
Gary Walker, UST Class A Operator
Gary Walker, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	24	11/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1268			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel		7/31/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		7/31/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: BENEFIS HEALTH CARE EAST CAMPUS UST
1101 26TH ST S
GREAT FALLS, MT 59405 CASCADE

Sys Fac ID: 07-06552

Last Inspected On: 9/22/2014

Operating Permit Renewal Date: 3/20/2018

Contact: Mike Battelson, (406) 727-3333

Owners/Operators: Benefis Health Care, Owner

(406)-455-5135

ATTN MIKE BATTLESAN MAINTENANCE
PO BOX 5013
GREAT FALLS MT 59403-5013

Mike Battleson, UST Class A Operator
Louis D'Antuono, UST Class A Operator
Troy England, UST Class A Operator
Kim Frank, UST Class A Operator
Mike Battleson, UST Class B Operator
Louis D'Antuono, UST Class B Operator
Kim Frank, UST Class B Operator
Troy England, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	14	3/30/2001	Concrete	Flexible Plastic	
4584	Yes	9/22/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel		12/12/2005	Deferred	Continuous Interstitial Monitor	
20,000			ILS-350 , Veeder Root		
4	07	8/22/2008	Fiberglass Reinforced Plastic	Steel	High Level Alarm
5190			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Jet Fuel			Automatic Tank Gauging 0.2	Deferred	
2,500			TLS-300 , Veeder Root		Yes

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: 15TH STREET SERVICE
1501 10TH AVE S
GREAT FALLS, MT 59405 CASCADE

Contact: Gary Maki, (406) 453-2070

Sys Fac ID: 07-07573
Last Inspected On: 12/8/2014
Operating Permit Renewal Date: 3/27/2018

Owners/Operators: Gary Maki, Owner (406)-453-2070 15TH STREET SERVICE
1501 10TH AVE S
GREAT FALLS MT 59405-2625

Gary Maki, UST Class A Operator
Gary Maki, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
5	27	1/16/1989	Steel Clad	Steel	Flapper Valve (Auto Shutoff)
3824			None	none	Yes
Currently in Use		1/16/1999	Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		12/8/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, MLLD Line Tightness Testing	
6,000		12/13/2011			
6	27	1/16/1989	Steel Clad	Steel	Flapper Valve (Auto Shutoff)
3825			None	none	Yes
Currently in Use		1/16/1999	Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		12/8/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, MLLD Line Tightness Testing	
4,000		12/13/2011			
7	27	1/16/1989	Steel Clad	Steel	Flapper Valve (Auto Shutoff)
3826			None	none	Yes
Currently in Use		1/16/1999	Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		12/8/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, MLLD Line Tightness Testing	
4,000		12/13/2011			

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: 15TH STREET SERVICE
1501 10TH AVE S
GREAT FALLS, MT 59405 CASCADE

Contact: Gary Maki, (406) 453-2070

Sys Fac ID: 07-07573
Last Inspected On: 12/8/2014
Operating Permit Renewal Date: 3/27/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
8	27	1/16/1989	Steel Clad	Steel	Flapper Valve (Auto Shutoff)
3827			None	none	Yes
Currently in Use		1/16/1999	Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		12/8/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, MLLD Line Tightness Testing	
4,000		12/13/2011			

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: HOLIDAY STATIONSTORE 273
1021 15TH ST N
GREAT FALLS, MT 59401 CASCADE
Contact: Jack Krueger, (406) 860-9083

Sys Fac ID: 07-08069
Last Inspected On: 9/3/2014
Operating Permit Renewal Date: 12/4/2017

Owners/Operators: Rocky Mountain Oil Co Inc, Owner (952)-830-8899 ATTN: ENVIRONMENTAL DIRECTOR
PO BOX 1224
MINNEAPOLIS MN 55437-1123

Stephen Reckinger, UST Class A Operator
Dean Townsend, UST Class A Operator
Ronald VanDenBroeke, UST Class A Operator
Christine Banach, UST Class B Operator
Jason Miksell, UST Class B Operator
Stephen Reckinger, UST Class B Global Operator
Travis Struckman, UST Class B Global Operator
Dean Townsend, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	17	5/15/1998	Steel Clad	Flexible Plastic	Ball Float Valve
2995			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		9/16/2009	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000		3/27/2014	TLS-350/Gilbarco EMC , Veeder Root	Automatic Tank Gauging 0.1, Continuous Interstitial Monitor	
5	17	5/15/1998	Steel Clad	Flexible Plastic	Ball Float Valve
2996			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		9/16/2009	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000		5/13/2014	TLS-350/Gilbarco EMC , Veeder Root	Automatic Tank Gauging 0.1, Continuous Interstitial Monitor	
6	17	5/15/1998	Steel Clad	Flexible Plastic	Ball Float Valve
2997			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		9/16/2009	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000		6/16/2014	TLS-350/Gilbarco EMC , Veeder Root	Automatic Tank Gauging 0.1, Continuous Interstitial Monitor	

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: THE STORE GREAT FALLS
3800 3RD AVE S
GREAT FALLS, MT 59405 CASCADE

Sys Fac ID: 07-08480

Last Inspected On: 1/26/2015

Operating Permit Renewal Date: 3/24/2018

Contact: Mark Schulte, (406) 453-3450

Owners/Operators: Mark Schulte, Owner (406)-453-3450 3800 3RD AVE S
GREAT FALLS MT 59405-3613
Judy Schulte, UST Class A Operator
Judy Schulte, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	30	12/7/1985	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1906			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		1/19/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		1/15/2015	TLS-300 , Veeder Root		
2	30	12/7/1985	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1907			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		1/19/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		1/15/2015	TLS-300 , Veeder Root		
3	26	12/7/1989	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1908			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline		1/19/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		1/15/2015	TLS-300 , Veeder Root		

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: TOWN PUMP INC GREAT FALLS 1
401 10TH AVE S
GREAT FALLS, MT 59405 CASCADE

Sys Fac ID: 07-08700

Last Inspected On: 4/5/2013

Operating Permit Renewal Date: 8/13/2016

Contact: Trent Biggers, (406) 497-6700

Owners/Operators: Town Pump Inc Butte, Owner (406)-782-9121 PO BOX 6000
BUTTE MT 59702-6000
Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	30	1/1/1986	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2391			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		4/2/2013	Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
10,000					
2	30	1/1/1986	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2392			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		4/2/2013	Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
10,000					
3	27	8/18/1988	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2393			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		4/2/2013	Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
10,000					
4	17	5/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2394			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		3/16/2010	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
10,000					

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: TOWN PUMP INC GREAT FALLS 1
401 10TH AVE S
GREAT FALLS, MT 59405 CASCADE

Sys Fac ID: 07-08700

Last Inspected On: 4/5/2013

Operating Permit Renewal Date: 8/13/2016

Contact: Trent Biggers, (406) 497-6700

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
5	17	5/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2395			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		3/16/2010	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
8,000					

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: TOWN PUMP INC GREAT FALLS 2
1400 10TH AVE S
GREAT FALLS, MT 59405 CASCADE

Sys Fac ID: 07-08701

Last Inspected On: 4/5/2013

Operating Permit Renewal Date: 8/13/2016

Contact: Trent Biggers, (406) 497-6700

Owners/Operators: Town Pump of Great Falls Inc, Owner (406)-497-6700 PO BOX 6000
BUTTE MT 59702-6000
Trent Biggers, UST Class A Operator
Megan Gretch, UST Class A Operator
Trent Biggers, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	26	1/4/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2396			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
10,000					
3	26	1/4/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2397			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000					
4	26	1/4/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2398			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000					

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: TOWN PUMP INC GREAT FALLS 2
1400 10TH AVE S
GREAT FALLS, MT 59405 CASCADE

Sys Fac ID: 07-08701
Last Inspected On: 4/5/2013
Operating Permit Renewal Date: 8/13/2016

Contact: Trent Biggers, (406) 497-6700

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
5	26	1/4/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2399			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
8,000					
6	26	1/4/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2400			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
4,000					

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: HOLIDAY STATIONSTORE 10
1601 FOX FARM RD
GREAT FALLS, MT 59404 CASCADE
Contact: Bary Moore, (406) 827-4314

Sys Fac ID: 07-09914
Last Inspected On: 9/3/2014
Operating Permit Renewal Date: 12/4/2017

Owners/Operators: Rocky Mountain Oil Co Inc, Owner (952)-830-8899 ATTN: ENVIRONMENTAL DIRECTOR
PO BOX 1224
MINNEAPOLIS MN 55437-1123

Jack Krueger Jr, UST Class A Operator
Stephen Reckinger, UST Class A Operator
Jolene Edmisten, UST Class B Operator
Casey Light, UST Class B Operator
Debbie Osweiler, UST Class B Operator
Joseph Wanago, UST Class B Operator
Travis Struckman, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
6	17	6/16/1998	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm, Ball Float Valve
1697			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	Yes
15,000		5/21/2014	TLS-350/Gilbarco EMC , Veeder Root	Automatic Tank Gauging 0.1	
7	17	6/16/1998	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm, Ball Float Valve
1698			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	Yes
8,000		5/11/2014	TLS-350/Gilbarco EMC , Veeder Root	Automatic Tank Gauging 0.1	
8	17	6/16/1998	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm, Ball Float Valve
1699			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
6,000		8/15/2014	TLS-350/Gilbarco EMC , Veeder Root	Automatic Tank Gauging 0.1	

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: Lithia Real Estate Inc
26 9TH ST S
GREAT FALLS, MT 59401 CASCADE

Sys Fac ID: 07-10262
Last Inspected On: 5/9/2014
Operating Permit Renewal Date: 7/5/2017

Contact: Brian Belderrain, (406) 727-2100

Owners/Operators: Bennett Motors Inc, Owner (406)-727-2100 PO BOX 2267
GREAT FALLS MT 59403-2267
DAN NOLAND, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	40	1/27/1976	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
430			None	None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Not Applicable
Gasoline			Stat. Inventory Reconciliation	Deferred	
1,998					

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: GREAT FALLS INTERNATIONAL AIRPORT FUEL FARM 1
1931 AIRPORT CT
GREAT FALLS, MT 59404 CASCADE

Sys Fac ID: 07-10676

Last Inspected On: 4/23/2013

Operating Permit Renewal Date: 10/11/2016

Contact: Bruce Sanford, (406) 727-3404

Owners/Operators: Great Falls International Airport, Owner (406)-727-3404 2800 TERMINAL DR
GREAT FALLS MT 59404-5501

Mike Cunningham, UST Class A Operator
Kent Funyak, UST Class A Operator
Rod Hall, UST Class A Operator
Jeremy Hill, UST Class A Operator
Chris Houghton, UST Class A Operator
LeeRoy Bollich, UST Class B Operator
Mike Cunningham, UST Class B Operator
Kent Funyak, UST Class B Operator
Rod Hall, UST Class B Operator
Jeremy Hill, UST Class B Operator
Jeff Hoock, UST Class B Operator
Chris Houghton, UST Class B Operator
Robert Konigsfeld, UST Class B Operator
Paul Puckett, UST Class B Operator
Stefan Reese, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	41	4/3/1974	Cathodically Protected Steel	No Piping	High Level Alarm
3747			Lined Interior/Impressed Current	None	Yes
Currently in Use			Not Required	U.S. Suction	Impressed Current
Jet Fuel		12/13/2011	Automatic Tank Gauging 0.2		
25,000					
2	41	4/3/1974	Cathodically Protected Steel	No Piping	High Level Alarm
3748			Lined Interior/Impressed Current	None	Yes
Currently in Use			Not Required	U.S. Suction	Impressed Current
Jet Fuel		12/13/2011	Automatic Tank Gauging 0.2		
25,000					

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: GREAT FALLS INTERNATIONAL AIRPORT FUEL FARM 1
1931 AIRPORT CT
GREAT FALLS, MT 59404 CASCADE
Contact: Bruce Sanford, (406) 727-3404

Sys Fac ID: 07-10676
Last Inspected On: 4/23/2013
Operating Permit Renewal Date: 10/11/2016

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	41	4/3/1974	Cathodically Protected Steel	No Piping	High Level Alarm
3746			Lined Interior/Impressed Current	None	Yes
Currently in Use			Not Required	U.S. Suction	Impressed Current
Jet Fuel		12/13/2011	Automatic Tank Gauging 0.2		
19,000					
4	41	4/3/1974	Cathodically Protected Steel	No Piping	High Level Alarm
3740			Lined Interior/Impressed Current	None	Yes
Currently in Use			Not Required	U.S. Suction	Impressed Current
Aviation Gas		12/13/2011	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2		
15,275					
5	41	4/3/1974	Cathodically Protected Steel	No Piping	High Level Alarm
3741			Lined Interior/Impressed Current	None	Yes
Currently in Use			Not Required	U.S. Suction	Impressed Current
Aviation Gas		12/13/2011	Automatic Tank Gauging 0.2		
15,275					
6	41	4/3/1974	Cathodically Protected Steel	No Piping	High Level Alarm
3743			Lined Interior/Impressed Current	None	Yes
Currently in Use			Not Required	U.S. Suction	Impressed Current
Jet Fuel		12/13/2011	Automatic Tank Gauging 0.2		
15,275					
7	41	4/3/1974	Cathodically Protected Steel	No Piping	High Level Alarm
3742			Lined Interior/Impressed Current	None	Yes
Currently in Use			Not Required	U.S. Suction	Impressed Current
Gasoline		12/13/2011	Automatic Tank Gauging 0.2		
15,275					

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: GREAT FALLS INTERNATIONAL AIRPORT FUEL FARM 1
1931 AIRPORT CT
GREAT FALLS, MT 59404 CASCADE
Contact: Bruce Sanford, (406) 727-3404

Sys Fac ID: 07-10676
Last Inspected On: 4/23/2013
Operating Permit Renewal Date: 10/11/2016

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
8	41	4/3/1974	Cathodically Protected Steel	No Piping	High Level Alarm
3745			Lined Interior/Impressed Current	None	Yes
Currently in Use			Not Required	U.S. Suction	Impressed Current
Jet Fuel		12/13/2011	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2		
15,000					
9	41	4/3/1974	Cathodically Protected Steel	No Piping	High Level Alarm
3744			Lined Interior/Impressed Current	None	Yes
Currently in Use			Not Required	U.S. Suction	Impressed Current
Jet Fuel		12/13/2011	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2		
15,275					
10	20	11/1/1995	Fiberglass Reinforced Plastic	No Piping	High Level Alarm
3749			None	None	Yes
Currently in Use			Not Required	U.S. Suction	Not Applicable
Jet Fuel		8/31/2006	Automatic Tank Gauging 0.2		
20,000					
11	20	11/1/1995	Fiberglass Reinforced Plastic	No Piping	High Level Alarm
3750			None	None	Yes
Currently in Use			Not Required	U.S. Suction	Not Applicable
Aviation Gas		8/31/2006	Automatic Tank Gauging 0.2		
20,000					

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: MEADOWLARK COUNTRY CLUB
300 COUNTRY CLUB BLVD
GREAT FALLS, MT 59404 CASCADE

Sys Fac ID: 07-11234

Last Inspected On: 1/12/2016

Operating Permit Renewal Date: 3/1/2019

Contact: Tim Furan, (406) 899-6846

Owners/Operators: Meadowlark Country Club, Owner (406)-453-6531 300 COUNTRY CLUB BLVD
GREAT FALLS MT 59404-3355
Tim Furan, UST Class A Operator
Tim Furan, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	24	5/23/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2317			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		1/12/2016	Automatic Tank Gauging 0.2	Deferred	
1,000			OPW 1500 , OPW		
3	24	5/23/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2318			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		1/12/2016	Automatic Tank Gauging 0.2	Deferred	
1,000			OPW 1500 , OPW		

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: RENTAL CAR SERVICE BUILDING
2700 AIRPORT DR
GREAT FALLS, MT 59404 CASCADE

Sys Fac ID: 07-12300

Last Inspected On: 4/23/2013

Operating Permit Renewal Date: 7/20/2016

Contact: Dwight Holman, (406) 453-7613

Owners/Operators: Great Falls International Airport, Owner (406)-727-3404 2800 TERMINAL DR
GREAT FALLS MT 59404-5501

Kent Funyak, UST Class A Operator
Rod Hall, UST Class A Operator
Chris Houghton, UST Class A Operator
Kent Funyak, UST Class B Operator
Rod Hall, UST Class B Operator
Chris Houghton, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	25	11/27/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
2704			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Deferred	
8,000					

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: MCLAUGHLIN RESEARCH INSTITUTE
1520 23RD ST S
GREAT FALLS, MT 59405 CASCADE

Sys Fac ID: 07-12790

Last Inspected On: 2/16/2016

Operating Permit Renewal Date: 7/16/2016

Contact: James R Toms, (406) 452-6208

Owners/Operators: Joe Amato, Owner (406)-799-4595 1520 23RD ST S
GREAT FALLS MT 59405-4900
Joe Amato, UST Class A Operator
Joe Amato, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	22	5/23/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2977			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor, MLLD Line Tightness Testing	
1,000		3/28/2013			

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: SUCH GROUP INTERNATIONAL INC
2224 VAUGHN RD
GREAT FALLS, MT 59404 CASCADE

Sys Fac ID: 07-13632

Last Inspected On: 4/30/2015

Operating Permit Renewal Date:

Contact: Will Bernhagon, (406) 252-9440

Owners/Operators: Such Group International Inc, Owner/Operator (406)-727-4144 PO BOX 2589
GREAT FALLS MT 59403

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	20	8/1/1995	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4389			None	Double-Walled	Yes
Temporarily Out of Use			Not Required	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
10,000					
2	20	8/1/1995	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4390			None	Double-Walled	Yes
Temporarily Out of Use			Not Required	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000					

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: FEDERAL AVIATION ADMIN ARSR 4
 BOOTLEGGERS RIDGE
 GREAT FALLS, MT 59401 CASCADE

Sys Fac ID: 07-13710

Last Inspected On: 6/9/2015

Operating Permit Renewal Date: 6/15/2018

Contact: Joe Konesky, (406) 788-8041

Owners/Operators: Federal Aviation Admin Great Falls, Owner

(406)-788-8041

2830 AIRPORT AVENUE A
 GREAT FALLS MT 59404-5544

Joe Konesky, UST Class A Operator

Joe Konesky, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	19	4/1/1996	Unknown	Flexible Plastic	
4564	Yes	6/9/2015	None	Double-Walled	Yes
Currently in Use			Auto Dialer	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
2,000			Other , Other		

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: HOLIDAY STATION STORE 59
601 NORTHWEST BYP
GREAT FALLS, MT 59404 CASCADE
Contact: Bary Moore, (406) 827-3498

Sys Fac ID: 07-13729
Last Inspected On: 9/3/2014
Operating Permit Renewal Date: 12/4/2017

Owners/Operators: Rocky Mountain Oil Co Inc, Owner (952)-830-8899 ATTN: ENVIRONMENTAL DIRECTOR
PO BOX 1224
MINNEAPOLIS MN 55437-1123

Jack Krueger Jr, UST Class A Operator
Stephen Reckinger, UST Class A Operator
FOSTER SENSIBAUGH, UST Class B Operator
Stephen Reckinger, UST Class B Global Operator
Travis Struckman, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	19	7/17/1996	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
3359			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		11/6/2012	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	Yes
12,000			TLS-350/Gilbarco EMC , Veeder Root	Automatic Tank Gauging 0.1, Continuous Interstitial Monitor	
2	19	7/17/1996	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
3360			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		11/6/2012	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	Yes
8,000			TLS-350/Gilbarco EMC , Veeder Root	Automatic Tank Gauging 0.1, Continuous Interstitial Monitor	
3	19	7/17/1996	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
3361			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		11/6/2012	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Automatic Tank Gauging 0.1, Continuous Interstitial Monitor	

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: CASCADE COUNTY SHERIFFS OFFICE
3800 ULM NORTH FRONTAGE RD
GREAT FALLS, MT 59404 CASCADE

Sys Fac ID: 07-13772

Last Inspected On: 9/2/2014

Operating Permit Renewal Date: 9/12/2017

Contact: Douglas Daniels, (406) 454-6834

Owners/Operators: Cascade County Sheriffs/Adult Detention, Owner/Operator (406)-454-6834 3800 ULM N FRONTAGE RD
GREAT FALLS MT 59404

Doug Daniels, UST Class A Operator
Charles Livingston, UST Class A Operator
Doug Daniels, UST Class B Operator
Charles Livingston, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	18	5/6/1997	Unknown	Flexible Plastic	Flapper Valve (Auto Shutoff)
537	Yes	9/2/2014	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel		9/2/2009	Deferred	Continuous Interstitial Monitor	
2,000			TLS-350/Gilbarco EMC , Veeder Root		
2	18	5/6/1997	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
4489			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	U.S. Suction	Galvanic
Waste Oil		8/1/2014	Continuous Interstitial Monitor	Deferred	
600		9/2/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: HOLIDAY #730
1428 3RD ST NW
GREAT FALLS, MT 59404 CASCADE
Contact: (952) 830-8899

Sys Fac ID: 56-13970
Last Inspected On: 11/5/2015
Operating Permit Renewal Date: 3/30/2019

Owners/Operators: Rocky Mountain Oil Inc, Owner (952)-830-8700 ATTN: ENVIRONMENTAL DIRECTOR
4567 AMERICAN BLVD W
BLOOMINGTON MN 55437
Holiday #730, Operator (952)-830-8747 1428 3RD ST NW
GREAT FALLS MT 59404
Robert Deninno, UST Class A Operator
Stephen Reckinger, UST Class A Operator
Dan Baker, UST Class B Operator
Curt Seaman, UST Class B Operator
James Sneed, UST Class B Operator
Jim Dundas, UST Class B Global Operator
Stephen Reckinger, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	15	7/7/2000	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4203			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000		10/20/2015	TLS-450 , Veeder Root	Continuous Interstitial Monitor	
2	15	7/7/2000	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4204			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		8/10/2015	TLS-450 , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: HOLIDAY #724
2260 10TH AVE S
GREAT FALLS, MT 59405 CASCADE

Contact: (952) 830-8899

Sys Fac ID: 56-13975
Last Inspected On: 12/7/2015
Operating Permit Renewal Date: 3/30/2019

Owners/Operators: Rocky Mountain Oil Inc, Owner (952)-830-8700 ATTN: ENVIRONMENTAL DIRECTOR
4567 AMERICAN BLVD W
BLOOMINGTON MN 55437

Holiday #724, Operator (952)-830-8747 2260 10TH AVE S
GREAT FALLS MT 59405

Robert Deninno, UST Class A Operator
Kevin Dyke, UST Class B Operator
Peter Garth, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	15	10/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4219			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000		8/23/2009	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	15	10/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4220			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		8/23/2009	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: TOWN PUMP INC GREAT FALLS 3
505 NORTHWEST BYP
GREAT FALLS, MT 59404 CASCADE

Sys Fac ID: 56-14016

Last Inspected On: 4/5/2013

Operating Permit Renewal Date: 8/13/2016

Contact: (406) 260-1700

Owners/Operators: Billings Holdings LLC, Owner (406)-497-6700 PO BOX 6000
BUTTE MT 59702-6000
Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	14	10/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4453			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		11/30/2005	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Yes
15,000		10/12/2006			
2	14	10/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4454			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		11/30/2005	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
10,000		10/12/2006			
3	14	10/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4455			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		11/30/2005	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
5,000		10/12/2006			
4	14	10/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4456			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		11/30/2005	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
10,000		10/12/2006			

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: TOWN PUMP INC GREAT FALLS 3
 505 NORTHWEST BYP
 GREAT FALLS, MT 59404 CASCADE
Contact: (406) 260-1700

Sys Fac ID: 56-14016
Last Inspected On: 4/5/2013
Operating Permit Renewal Date: 8/13/2016

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
5	14	10/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4457			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		11/30/2005	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
5,000		10/12/2006			

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: SAMS CLUB 6379
401 NORTHWEST BYP
GREAT FALLS, MT 59404 CASCADE

Sys Fac ID: 56-14065
Last Inspected On: 7/11/2014
Operating Permit Renewal Date: 10/16/2017

Contact: Mark Johnson, (406) 585-8005

Owners/Operators: Sams West Inc, Owner (479)-204-2330 702 SW 8TH ST
BENTONVILLE AR 72716-6209

Kevin E Allen, UST Class A Operator
Bobbi Brown, UST Class A Operator
JOHNNY CAVILL, UST Class A Operator
Donald Elderbaum, UST Class A Operator
Steven Hodge, UST Class A Operator
Josh Kelly, UST Class A Operator
Joseph Khan, UST Class A Operator
Michael Lawson, UST Class A Operator
Teddy Moulton, UST Class A Operator
Denise Purvis, UST Class A Operator
Bobbi Brown, UST Class B Operator
Michael Lawson, UST Class B Operator
Phillip Patat, UST Class B Operator
Denise Purvis, UST Class B Operator
Kevin E Allen, UST Class B Global Operator
JOHNNY CAVILL, UST Class B Global Operator
Donald Elderbaum, UST Class B Global Operator
Steven Hodge, UST Class B Global Operator
Josh Kelly, UST Class B Global Operator
Joseph Khan, UST Class B Global Operator
Michael Lawson, UST Class B Global Operator
Teddy Moulton, UST Class B Global Operator
James Ray, UST Class B Global Operator
Rick Weaver, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: SAMS CLUB 6379
401 NORTHWEST BYP
GREAT FALLS, MT 59404 CASCADE

Contact: Mark Johnson, (406) 585-8005

Sys Fac ID: 56-14065
Last Inspected On: 7/11/2014
Operating Permit Renewal Date: 10/16/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	13	8/5/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
4702			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor	MLLD Line Tightness Testing	
20,000		3/4/2014	EECO 2000 , EMCO Electronics	Continuous Interstitial Monitor	
2	13	8/5/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
4703			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor	MLLD Line Tightness Testing	
20,000		3/4/2014	EECO 2000 , EMCO Electronics	Continuous Interstitial Monitor	
3	13	8/5/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
4704			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor	MLLD Line Tightness Testing	
20,000		3/4/2014	EECO 2000 , EMCO Electronics	Continuous Interstitial Monitor	

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: GREAT FALLS FLYING J
3715 31ST ST SW
GREAT FALLS, MT 59404 CASCADE
Contact: Shane Swiegert, (406) 497-6700

Sys Fac ID: 56-14148
Last Inspected On: 12/28/2015
Operating Permit Renewal Date: 4/9/2019

Owners/Operators: Montana Innovations LLC, Owner (406)-497-6700 PO BOX 6000
BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Trent Biggers, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Trent Biggers, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	11	2/25/2005	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
4956			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
20,000		10/30/2008	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	11	2/25/2005	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
4957			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
20,000		10/30/2008	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	11	2/25/2005	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
4958			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
20,000		10/30/2008	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: GREAT FALLS FLYING J
3715 31ST ST SW
GREAT FALLS, MT 59404 CASCADE

Sys Fac ID: 56-14148

Last Inspected On: 12/28/2015

Operating Permit Renewal Date: 4/9/2019

Contact: Shane Swiegert, (406) 497-6700

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	11	1/25/2005	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
4959			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconciliation	Stat. Inventory Reconciliation	
12,000		10/30/2008	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: SMITH'S 166 FUEL CENTER
1601 MARKET PLACE DR
GREAT FALLS, MT 59401 CASCADE

Sys Fac ID: 60-15217

Last Inspected On: 11/12/2015

Operating Permit Renewal Date: 4/16/2019

Contact: David Harris, (801) 974-1206

Owners/Operators: David Harris, Owner (801)-974-1206 PO BOX 244
WINNETT MT 59087-0244

Kerry Busey, UST Class A Operator
Gary Dotseth, UST Class A Operator
Todd Dotseth, UST Class A Operator
David Harris, UST Class A Operator
Todd Dotseth, UST Class B Operator
Kerry Busey, UST Class B Global Operator
Gary Dotseth, UST Class B Global Operator
David Harris, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	03	12/1/2012	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve, High Level Alarm
5395			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
20,000			TLS-450 , Veeder Root	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Not Listed	Yes
2	03	12/1/2012	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve, High Level Alarm
5396			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor, Not Listed	Yes

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: SMITH'S 166 FUEL CENTER
1601 MARKET PLACE DR
GREAT FALLS, MT 59401 CASCADE

Sys Fac ID: 60-15217

Last Inspected On: 11/12/2015

Operating Permit Renewal Date: 4/16/2019

Contact: David Harris, (801) 974-1206

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	03	12/1/2012	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve, High Level Alarm
5397			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor, Not Listed	Yes

Facility Summary in CASCADE County in the City of MALMSTROM A F B

Location: MALMSTROM AFB BLDG 82110 COAL HEAT PLANT
 PERIMETER RD
 MALMSTROM A F B, MT 59402 CASCADE

Sys Fac ID: 07-08942

Last Inspected On: 8/1/2015

Operating Permit Renewal Date:

Contact: Jim Hodges,

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
 MALMSTROM AFB MT 59402-7536
 Lana Hedlund, UST Class A Operator
 Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	22	7/2/1993	Unknown	Flexible Plastic	High Level Alarm
101	Yes	8/29/2012	None	Double-Walled	Yes
Temporarily Out of Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
6,000					

Facility Summary in CASCADE County in the City of MALMSTROM A F B

Location: MALMSTROM AFB BLDG 500
 21 77TH ST N
 MALMSTROM A F B, MT 59402 CASCADE
Contact: Jim Hodges,

Sys Fac ID: 07-08954
Last Inspected On: 8/1/2015
Operating Permit Renewal Date: 12/16/2018

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
 MALMSTROM AFB MT 59402-7536
 Lana Hedlund, UST Class A Operator
 James Hodges, UST Class A Operator
 David Degolier, UST Class B Operator
 Lana Hedlund, UST Class B Global Operator
 James Hodges, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
7	15	11/22/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
4227		7/31/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
12,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CASCADE County in the City of MALMSTROM A F B

Location: MALMSTROM AFB BLDG 295
1ST ST
MALMSTROM A F B, MT 59402 CASCADE

Contact: Jim Hodges,

Sys Fac ID: 07-10726
Last Inspected On: 8/1/2015
Operating Permit Renewal Date:

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Leigland, UST Class A Operator
James Leigland, UST Class B Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	22	6/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
146			Double-Walled	Double-Walled	Yes
Temporarily Out of Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
600					

Facility Summary in CASCADE County in the City of MALMSTROM A F B

Location: MALMSTROM AFB BLDG 1480 1482
 6705 FLIGHTLINE DR
 MALMSTROM A F B, MT 59402 CASCADE
Contact: Jim Hodges, (406) 731-6167

Sys Fac ID: 07-10733
Last Inspected On: 8/1/2015
Operating Permit Renewal Date: 12/16/2018

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
 MALMSTROM AFB MT 59402-7536
 Lana Hedlund, UST Class A Operator
 RODNEY BORGER, UST Class B Global Operator
 Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	19	8/1/1996	Fiberglass Reinforced Plastic	Steel	Positive Shutoff, High Level Alarm
4325		7/31/2015	Double-Walled	none	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Jet Fuel		7/31/2015	Continuous Interstitial Monitor	Continuous Interstitial Monitor, MLLD Line Tightness Testing	
4,000		11/26/2012	Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in CASCADE County in the City of MALMSTROM A F B

Location: AAFES SHOPPING CENTER BLDG 1340
7200 PERIMETER ROAD
MALMSTROM A F B, MT 59402 CASCADE

Contact: Lana Hedlund, (406) 731-6175

Sys Fac ID: 60-15199
Last Inspected On: 8/1/2015
Operating Permit Renewal Date: 1/2/2019

Owners/Operators: Malmstrom AFB, Owner (406)-731-6167 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Josh Probst, Operator (214)-312-4616 3911 SO. WALTON WALKER BLVD.
DALLAS TX 75236

Sonya Coker, UST Class A Operator
Lana Hedland, UST Class A Operator
Fatima Quintanilla, UST Class A Operator
Sonya Coker, UST Class B Operator
Fatima Quintanilla, UST Class B Operator
Sonya Coker, UST Class B Global Operator
Lana Hedland, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	04	9/1/2011	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
5329			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		6/11/2012	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor	Yes
2	04	9/1/2011	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
5330			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		6/11/2012	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
20,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor	Yes

Facility Summary in CASCADE County in the City of MALMSTROM AFB

Location: MALMSTROM AFB THREE BAY HANGAR
 7101 FLIGHTLINE DR BLDG 1440
 MALMSTROM AFB, MT 59402 CASCADE
Contact: Lana Hedlund, (406) 731-6175

Sys Fac ID: 07-07044
Last Inspected On: 8/1/2015
Operating Permit Renewal Date:

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
 MALMSTROM AFB MT 59402-7536
 Lana Hedlund, UST Class A Operator
 James Hodges, UST Class A Operator
 Lana Hedlund, UST Class B Global Operator
 James Hodges, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	22	4/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Positive Shutoff, High Level Alarm
100			Double-Walled	Double-Walled	Yes
Temporarily Out of Use			Not Required	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	MLLD Line Tightness Testing	
750		8/28/2012		Continuous Interstitial Monitor	

Facility Summary in CASCADE County in the City of MALMSTROM AFB

Location: MILITARY VEHICLE REFUELING SITE BLDG 448
7832 FLIGHTLINE DR
MALMSTROM AFB, MT 59402 CASCADE
Contact: (406) 731-6175

Sys Fac ID: 56-14116
Last Inspected On: 8/1/2015
Operating Permit Renewal Date: 12/16/2018

Owners/Operators: Malmstrom AFB, Owner (406)-731-6167 39 78TH ST N
MALMSTROM AFB MT 59402-7536
Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	10	6/15/2005	Concrete	Flexible Plastic	High Level Alarm
4971	Yes	7/31/2015	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
>B20			Deferred	Continuous Interstitial Monitor	
60,000			TLS-350/Gilbarco EMC , Veeder Root		
3	10	8/5/2005	Concrete	Flexible Plastic	High Level Alarm
4972	Yes	7/31/2015	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
20,000			TLS-350/Gilbarco EMC , Veeder Root		
4	10	8/5/2005	Concrete	Flexible Plastic	High Level Alarm
5037	Yes	7/31/2015	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
>E15			Deferred	Continuous Interstitial Monitor	
10,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CASCADE County in the City of MONARCH

Location: COUGAR CANYON LODGE & ESCAPE
5012 US HIGHWAY 89 S
MONARCH, MT 59463 CASCADE

Sys Fac ID: 07-01874

Last Inspected On: 2/12/2016

Operating Permit Renewal Date:

Contact: Brett Smith, (406) 277-3314

Owners/Operators: Mark Properties LLC, Owner

PO BOX 884

Three Rivers Petroleum Services, Operator

(406)-439-1805

MONARCH MT 59463

PO BOX 4172

HELENA MT 59604-4172

Kurt Gallagher, UST Class A Operator

Kurt Gallagher, UST Class B Operator

Judy McCurdie, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	23	9/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2979			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Vapor Monitoring	MLLD Line Tightness Testing	
2,000		12/7/2012			

Facility Summary in CASCADE County in the City of MONARCH

Location: MALMSTROM AFB A 5
US HIGHWAY 89
MONARCH, MT 59463 CASCADE

Sys Fac ID: 07-08979
Last Inspected On: 9/19/2014
Operating Permit Renewal Date: 9/25/2017

Contact: Jim Hodges,

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536
Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	23	6/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
110		9/3/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			ILS-350 , Veeder Root		

Facility Summary in CASCADE County in the City of MONARCH

Location: MALMSTROM AFB A 6
US HIGHWAY 89
MONARCH, MT 59463 CASCADE

Sys Fac ID: 07-08980
Last Inspected On: 9/19/2014
Operating Permit Renewal Date: 9/25/2017

Contact: Jim Hodges,

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536
Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	23	6/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
111		9/3/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			ILS-350 , Veeder Root		

Facility Summary in CASCADE County in the City of MONARCH

Location: MALMSTROM AFB A 7
US HIGHWAY 89
MONARCH, MT 59463 CASCADE

Sys Fac ID: 07-08981
Last Inspected On: 9/22/2014
Operating Permit Renewal Date: 10/7/2017

Contact: Jim Hodges,

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536
Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	23	6/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
112		9/4/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			ILS-350 , Veeder Root		

Facility Summary in CASCADE County in the City of MONARCH

Location: MALMSTROM AFB A 8
US HIGHWAY 89
MONARCH, MT 59463 CASCADE

Sys Fac ID: 07-08982
Last Inspected On: 9/19/2014
Operating Permit Renewal Date: 9/25/2017

Contact: Jim Hodges,

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536
Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	23	6/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
113		9/4/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	Safe Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			ILS-350 , Veeder Root		

Facility Summary in CASCADE County in the City of NEIHART

Location: BOBS BAR UST
107 MAIN ST
NEIHART, MT 59465 CASCADE

Sys Fac ID: 07-09274

Last Inspected On: 11/25/2014

Operating Permit Renewal Date: 5/16/2018

Contact: Tony Juntunen, (406) 236-5955

Owners/Operators: Anthony E Juntunen, Owner (406)-236-5955 PO BOX 37
NEIHART MT 59465-0037
Anthony E Juntunen, UST Class A Operator
Anthony E Juntunen, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	29	2/16/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1455			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		11/25/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Not Listed	
1,500					
2	29	2/16/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1456			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		11/25/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Not Listed	
1,500					

Facility Summary in CASCADE County in the City of SAND COULEE

Location: CENTERVILLE ELEMENTARY SCHOOL
 693 STOCKETT RD
 SAND COULEE, MT 59472 CASCADE
Contact: Ed Cutlip, (406) 736-5123

Sys Fac ID: 07-11037
Last Inspected On: 3/28/2014
Operating Permit Renewal Date: 4/3/2017

Owners/Operators: Centerville School, Owner (406)-736-5123 693 STOCKETT RD
 SAND COULEE MT 59472-9757
 Steve Beaumont, UST Class A Operator
 Steve Beaumont, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	29	4/30/1986	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
606			None	Double-Walled	Yes
Currently in Use			Not Required	Gravity Feed	Galvanic
Heating Oil		3/28/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		3/28/2014		Continuous Interstitial Monitor	

Facility Summary in CASCADE County in the City of SIMMS

Location: CURTISS SERVICE CENTER
12742 MT HIGHWAY 200
SIMMS, MT 59477 CASCADE

Sys Fac ID: 07-01612

Last Inspected On: 4/24/2014

Operating Permit Renewal Date: 7/30/2017

Contact: Robert Curtiss, (406) 264-5222

Owners/Operators: Robert D Curtiss, Owner (406)-264-5640 PO BOX 306
SIMMS MT 59477-0306
Robert D Curtiss, UST Class A Operator
Robert D Curtiss, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
6	16	11/1/1999	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4124			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		4/10/2014	TLS-350/Gilbarco EMC , Veeder Root		
7	16	11/1/1999	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4125			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		4/10/2014	TLS-350/Gilbarco EMC , Veeder Root		
8	16	11/1/1999	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4126			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		4/10/2014	TLS-350/Gilbarco EMC , Veeder Root		
9	16	11/1/1999	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4127			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		4/10/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CASCADE County in the City of SIMMS

Location: MALMSTROM AFB G 2
MT HIGHWAY 200
SIMMS, MT 59477 CASCADE

Sys Fac ID: 07-09042

Last Inspected On: 9/17/2015

Operating Permit Renewal Date: 9/22/2018

Contact: Jim Hodges,

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator

James Hodges, UST Class A Operator

Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	23	6/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
117		9/9/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in CASCADE County in the City of SIMMS

Location: MALMSTROM AFB H 7
MT HIGHWAY 200
SIMMS, MT 59477 CASCADE

Sys Fac ID: 07-09058

Last Inspected On: 9/17/2015

Operating Permit Renewal Date: 9/22/2018

Contact: Jim Hodges,

Owners/Operators: 341 CES CEANQ, Owner

(406)-731-6188

39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator

Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	24	9/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
124		6/10/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in CASCADE County in the City of SIMMS

Location: MALMSTROM AFB G 01
MT HIGHWAY 200
SIMMS, MT 59477 CASCADE

Sys Fac ID: 25-09041

Last Inspected On: 9/17/2015

Operating Permit Renewal Date: 9/22/2018

Contact: Jim Hodges, (406) 731-6167

Owners/Operators: 341 CES CEANQ, Owner

(406)-731-6188

39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
Ricardo Andrillon, UST Class B Operator
Glen Beck, UST Class B Operator
Allen Brooks, UST Class B Operator
Jonathan Buesch, UST Class B Operator
John Corbett, UST Class B Operator
David Cosner, UST Class B Operator
Ryan Cox, UST Class B Operator
Brian Day, UST Class B Operator
David Degolier, UST Class B Operator
Patrick Ellis, UST Class B Operator
Hudson English, UST Class B Operator
Paul Floyd, UST Class B Operator
Dustin Hemingway, UST Class B Operator
Aaron Hill, UST Class B Operator
William Hoffmeister, UST Class B Operator
Shane Hofstad, UST Class B Operator
Bethany Kent, UST Class B Operator
James Knudsen, UST Class B Operator
Ryan Kofoed, UST Class B Operator
Jeff Laird, UST Class B Operator
Damon McCarty, UST Class B Operator
Kieth Mcllwain, UST Class B Operator
Brian McVay, UST Class B Operator
Ronald Miller, UST Class B Operator
Michael Murieen, UST Class B Operator
Jeff Nelson, UST Class B Operator
Patrick Noppenberg, UST Class B Operator
Shawn O'Grady, UST Class B Operator
Chris Ploof, UST Class B Operator
Issac Price, UST Class B Operator
Brian Rayner, UST Class B Operator

Facility Summary in CASCADE County in the City of SIMMS

Location: MALMSTROM AFB G 01
MT HIGHWAY 200
SIMMS, MT 59477 CASCADE

Sys Fac ID: 25-09041

Last Inspected On: 9/17/2015

Operating Permit Renewal Date: 9/22/2018

Contact: Jim Hodges, (406) 731-6167

Cameron Smith, UST Class B Operator
Jimmy Sonefelt, UST Class B Operator
Michael Stokes, UST Class B Operator
Kyle Topp, UST Class B Operator
Jason Vike, UST Class B Operator
James Wooderchak, UST Class B Operator
Paul Ziemba, UST Class B Operator
Paul Floyd, UST Class B Global Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	53	6/2/1962	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
250		9/9/2015	Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Impressed Current
Diesel		7/31/2013	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CASCADE County in the City of SIMMS

Location: MALMSTROM AFB G 6
ROAD 287
SIMMS, MT 59477 CASCADE
Contact: Jim Hodges, (406) 731-6167

Sys Fac ID: 25-09046
Last Inspected On: 9/18/2015
Operating Permit Renewal Date: 9/23/2018

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536
Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	23	5/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
251		9/16/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in CASCADE County in the City of SIMMS

Location: MALMSTROM AFB G 7
MT HIGHWAY 200
SIMMS, MT 59477 CASCADE

Sys Fac ID: 25-09047

Last Inspected On: 9/21/2015

Operating Permit Renewal Date: 9/22/2018

Contact: Jim Hodges, (406) 731-6167

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator

James Hodges, UST Class A Operator

Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	23	5/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
4271		9/16/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in CASCADE County in the City of SIMMS

Location: MALMSTROM AFB G 8
MT HIGHWAY 200
SIMMS, MT 59477 CASCADE

Sys Fac ID: 25-09048

Last Inspected On: 9/21/2015

Operating Permit Renewal Date: 9/22/2018

Contact: Jim Hodges, (406) 731-6167

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator

James Hodges, UST Class A Operator

Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	23	5/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
253		9/16/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in CASCADE County in the City of SIMMS

Location: MALMSTROM AFB G 11
MT HIGHWAY 200
SIMMS, MT 59477 CASCADE

Sys Fac ID: 25-09051

Last Inspected On: 9/17/2015

Operating Permit Renewal Date: 9/22/2018

Contact: Jim Hodges, (406) 731-6167

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator

James Hodges, UST Class A Operator

Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	26	5/21/1989	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
256		9/9/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in CASCADE County in the City of SIMMS

Location: MALMSTROM AFB H 8
MT HIGHWAY 21
SIMMS, MT 59477 CASCADE

Sys Fac ID: 25-09059

Last Inspected On: 9/17/2015

Operating Permit Renewal Date: 9/22/2018

Contact: Jim Hodges, (406) 731-6167

Owners/Operators: 341 CES CEANQ, Owner

(406)-731-6188

39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator

Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	24	9/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
257		6/10/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in CASCADE County in the City of STOCKETT

Location: MALMSTROM AFB A 9
ROAD 227
STOCKETT, MT 59480 CASCADE

Contact: Jim Hodges,

Sys Fac ID: 07-08983
Last Inspected On: 9/19/2014
Operating Permit Renewal Date: 9/25/2017

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator
James Hodges, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	23	5/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
114		9/4/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			ILS-350 , Veeder Root		

Facility Summary in CASCADE County in the City of STOCKETT

Location: MALMSTROM AFB I 2
ROAD 226
STOCKETT, MT 59480 CASCADE

Sys Fac ID: 07-09064
Last Inspected On: 9/8/2015
Operating Permit Renewal Date: 9/22/2018

Contact: Jim Hodges,

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536
Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	24	10/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
126		6/16/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in CASCADE County in the City of SUN RIVER

Location: MALMSTROM AFB H 4
US HIGHWAY 89
SUN RIVER, MT 59483 CASCADE

Sys Fac ID: 07-09055

Last Inspected On: 9/18/2015

Operating Permit Renewal Date: 9/22/2018

Contact: Jim Hodges,

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536
Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	24	9/1/1991	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
121		9/14/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000		4/17/2015	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CASCADE County in the City of SUN RIVER

Location: MALMSTROM AFB H 5
US HIGHWAY 89
SUN RIVER, MT 59483 CASCADE

Sys Fac ID: 07-09056

Last Inspected On: 9/18/2015

Operating Permit Renewal Date: 9/22/2018

Contact: Jim Hodges,

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536
Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	24	9/1/1991	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
122		9/11/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CASCADE County in the City of ULM

Location: MALMSTROM AFB I 7
INTERSTATE 15
ULM, MT 59485 CASCADE

Sys Fac ID: 07-09069

Last Inspected On: 9/9/2015

Operating Permit Renewal Date: 9/22/2018

Contact: Jim Hodges,

Owners/Operators: 341 CES CEANQ, Owner

(406)-731-6188

39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator

Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	23	5/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
131		6/16/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in CASCADE County in the City of ULM

Location: MALMSTROM AFB I 11
INTERSTATE 15
ULM, MT 59485 CASCADE

Sys Fac ID: 07-09073

Last Inspected On: 9/21/2015

Operating Permit Renewal Date: 9/22/2018

Contact: Jim Hodges,

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536
Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	24	10/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
134		6/12/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in CASCADE County in the City of ULM

Location: MOUNTAIN VIEW CO OP
2 MILLEGAN RD
ULM, MT 59485 CASCADE

Sys Fac ID: 56-13797

Last Inspected On: 8/17/2014

Operating Permit Renewal Date: 11/14/2017

Contact: Dan Morano, (406) 453-2435

Owners/Operators: Mountain View Coop, Owner/Operator

(406)-453-2435

ATTN DAVE DOUGLAS
2200 OLD HAVRE HWY
BLACK EAGLE MT 59414-1043

David Douglas, UST Class A Operator
Charles Niswanger, UST Class A Operator
Robin Niswanger, UST Class A Operator
John Malley, UST Class B Operator
Charles Niswanger, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	18	10/1/1997	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
4428			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
6,000		7/21/2011	TLS-350/Gilbarco EMC , Veeder Root		
2	18	10/1/1997	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
4429			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
6,000		7/21/2011	TLS-350/Gilbarco EMC , Veeder Root		
3	18	10/1/1997	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
4430			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000		7/21/2011	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CASCADE County in the City of VAUGHN

Location: VALLEY COUNTRY STORE INC
133 US HIGHWAY 89
VAUGHN, MT 59487 CASCADE

Sys Fac ID: 07-05008

Last Inspected On: 5/8/2013

Operating Permit Renewal Date: 6/30/2016

Contact: Cory Eli, (406) 799-0128

Owners/Operators: Valley Country Store Inc, Owner (406)-965-3962 PO BOX 65
VAUGHN MT 59487-0065
Cory Eli, UST Class A Operator
Cory Eli, UST Class B Operator
Cory Eli, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
5	18	4/1/1997	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
2208			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
10,000		1/20/2010			
6	18	4/1/1997	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
2209			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
4,000		1/20/2010			
7	18	4/1/1997	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
2210			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
4,000		1/20/2010			

Facility Summary in CASCADE County in the City of VAUGHN

Location: MALMSTROM AFB I 10
INTERSTATE 15
VAUGHN, MT 59487 CASCADE

Sys Fac ID: 07-09072

Last Inspected On: 9/21/2015

Operating Permit Renewal Date: 9/22/2018

Contact: Jim Hodges,

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536
Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	24	8/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
133		6/12/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in CASCADE County in the City of VAUGHN

Location: MALMSTROM AFB J 8
INTERSTATE 15
VAUGHN, MT 59487 CASCADE

Sys Fac ID: 07-09081

Last Inspected On: 9/21/2015

Operating Permit Renewal Date: 9/22/2018

Contact: Jim Hodges,

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator

James Hodges, UST Class A Operator

Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	24	8/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
135		9/14/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in CASCADE County in the City of VAUGHN

Location: MALMSTROM AFB J 9
INTERSTATE 15
VAUGHN, MT 59487 CASCADE

Sys Fac ID: 07-09082

Last Inspected On: 9/21/2015

Operating Permit Renewal Date: 9/22/2018

Contact: Jim Hodges,

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator

James Hodges, UST Class A Operator

Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	24	8/1/1991	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
136		9/15/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in CASCADE County in the City of VAUGHN

Location: MALMSTROM AFB H 3
INTERSTATE 15
VAUGHN, MT 59487 CASCADE

Sys Fac ID: 50-09054

Last Inspected On: 9/14/2015

Operating Permit Renewal Date: 9/23/2018

Contact: Jim Hodges, (406) 731-6167

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536
Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	24	9/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
313		6/9/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in CASCADE County in the City of VAUGHN

Location: MALMSTROM AFB J 10
INTERSTATE 15
VAUGHN, MT 59487 CASCADE

Sys Fac ID: 50-09083

Last Inspected On: 9/21/2015

Operating Permit Renewal Date: 9/22/2018

Contact: Jim Hodges, (406) 731-6167

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator

James Hodges, UST Class A Operator

Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	24	8/1/1991	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
319		9/15/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000		5/29/2015	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CASCADE County in the City of VAUGHN

Location: GLACIER GATEWAY
99 US HIGHWAY 89
VAUGHN, MT 59487 CASCADE

Sys Fac ID: 56-13783

Last Inspected On: 2/2/2015

Operating Permit Renewal Date: 4/9/2018

Contact: Jake Neil, (406) 799-6499

Owners/Operators: NCI Tech Company LLC, Owner

(406)-965-9014

PO BOX 509
VAUGHN MT 59487

Glacier Gateway, Operator

(406)-965-9014

PO BOX 509
VAUGHN MT 59487

Kevin Enochs, UST Class A Operator

KEVIN FRANCIS, UST Class A Operator

Jake Neil, UST Class A Operator

Kay Neil, UST Class A Operator

Shalina Abrams, UST Class B Operator

JENNA BLAIR, UST Class B Operator

Bridget Bowen, UST Class B Operator

Andrea Bowie, UST Class B Operator

Jenifer Colden, UST Class B Operator

Amy Evans, UST Class B Operator

Vicki Ferda, UST Class B Operator

Christine Igel, UST Class B Operator

Janet Jensen, UST Class B Operator

Vicki Kriedeman, UST Class B Operator

Barbara Matthews, UST Class B Operator

Aaron McConnell, UST Class B Operator

Jake Neil, UST Class B Operator

Kay Neil, UST Class B Operator

Debbie Pengilly, UST Class B Operator

Roy Powell, UST Class B Operator

Matthew Schnittgen, UST Class B Operator

Justin Vallier, UST Class B Operator

Allicia Wick, UST Class B Operator

Josh Wick, UST Class B Operator

Leigh Wilson, UST Class B Operator

Marilyn Hutton, UST Class B Global Operator

BRENDA PISCHKE, UST Class B Global Operator

Helen Taylor, UST Class B Global Operator

Facility Summary in CASCADE County in the City of VAUGHN

Location: GLACIER GATEWAY
99 US HIGHWAY 89
VAUGHN, MT 59487 CASCADE

Contact: Jake Neil, (406) 799-6499

Sys Fac ID: 56-13783
Last Inspected On: 2/2/2015
Operating Permit Renewal Date: 4/9/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	18	6/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
3444			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			TLS-300 , Veeder Root	Continuous Interstitial Monitor	
2	18	6/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
3445			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			TLS-300 , Veeder Root	Continuous Interstitial Monitor	
3	18	6/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
3446			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000			TLS-300 , Veeder Root	Continuous Interstitial Monitor	
4	18	6/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
3447			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000			TLS-300 , Veeder Root	Continuous Interstitial Monitor	